

City of Portland, Maine - Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 410-418 FOLEY ST		Owner: JOE SOLEY		Phone: 774-8300		Permit No: 001367	
Owner Address: PO BOX 367 PORTLAND ME		Lessee/Buyer's Name: *** ALLIED RESOURCES 188 MIDDLE ST		Phone:		Business Name:	
Contractor Name: REX REVIEWING OPTIONS DO ONE YET		Address:		Phone:		Permit Issued: NOV 30 2000	
Past Use: COMMERCIAL GIFT SHOP		Proposed Use: REST. LOUNGE		COST OF WORK: \$ 2,000		PERMIT FEE: \$ 36.00	
Proposed Project Description: CHANGE OF USE FROM RETAIL TO REST. LOUNGE INTER. REMO.		FIRE DEPT. <input type="checkbox"/> Approved <input checked="" type="checkbox"/> Denied		INSPECTION: Use Group FB Type B			
		Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>			
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied			
Permit Taken By: K		Date Applied For: NOV 20 2000					

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

781-389-3679 cell
1-800-609-3505
PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT		ADDRESS:		DATE: NOV 20 2000 K		PHONE:	
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE						PHONE:	

Zoning Approval:
 CBL: **B-3**
 032-N-010
 Special Zone or Reviews:
 Shoreland
 Wetland
 Flood Zone
 Subdivision
 Site Plan major minor imm

Zoning Appeal:
 Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation:
 Not in District or Landmark
 Does Not Require Review
 Requires Review

Action: **Exterior**
 Approved
 Approved with Conditions
 Denied

Date: *review*

PERMIT ISSUED WITH REQUIREMENTS
CEO DISTRICT

COMMENTS

11/22/00 Spoke with Jonathan Pratt the license inspector for City Clerks, Next wed. he & Lt. MacDougal will be inspecting for license compliance - on hold until I hear from Jonathan - S

11/30/00 Met w/ Lt. MacDougal, et al on site. Question re: tread + rise also on door size from second floor. A

12/1/00 In office w/ T. Manning, PSH, et al. Tread + rise must be 7" x 11". Door size must be 44". Second floor may not be used for public access until changes are made and CO/O issued. A

12/19/00 CO/O for 1st Floor - public access - Bar/Sustain
2nd Floor - employees only

001367
CBL 32-N-10

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____