Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/17/15

NFPA 13R sprinkler check list

4 Is this check list applicable? no

What edition of NFPA 13R is the designed to? _____

Building construction type: _____

Will the sprinkler system provide complete or partial coverage of the building? _____

Will covered exterior balconies, decks and ground floor patios be sprinklered? _____

Size of riser assembly: _____

Fire department connection- number of 2 ½" inlets: _____

Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: _____

Is the nearest fire hydrant within 100 ft. of the FDC? _____

The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? _____

NFPA 13 sprinkler check list

4 Is this check list applicable? yes

4 What edition of NFPA 13 is the designed to? 2010

4 Building construction type: 3B

4 Will the sprinkler system provide complete or partial coverage of the building? complete

4 System type (See NFPA 13:3.4): wet

4 NFPA 13 Occupancy Classification (Hazard): Ordinary hazard 2, 1 & Ligh

4 Is the structure high-rise (see NFPA 101:3.3.32.7)? no

4 Size of riser assembly: 2 1/2

4 Fire department connection- number of 2 ½" inlets: 1

4 Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: by owner

4 Is the nearest fire hydrant within 100 ft. of the FDC? yes

4 The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? yes

NFPA 14 standpipe check list

4 Is this check list applicable? no

What edition of NFPA 14 is the designed to? _____

Building Inspections Division · 389 Congress Street · Portland, Maine 04101 · (207) 874-8703 · FACSIMILE (207) 874-8716 · TTY (207) 874-8936