KEY NOTES:

F01...
COMBINATION SMOKE / CO DETECTOR
WITH SOUNDER BASE. UNIT SHALL SIGNAL
A TROUBLE ALARM AT FIRE ALARM PANEL
UPON ACTIVATION.

A1 THIRD FLOOR POWER & SYSTEMS

SCALE: 1/4" = 1'-0"

KEY NOTES:

F01...
COMBINATION SMOKE / CO DETECTOR
WITH SOUNDER BASE. UNIT SHALL SIGNAL
A TROUBLE ALARM AT FIRE ALARM PANEL
UPON ACTIVATION.

A2 FOURTH FLOOR POWER & SYSTEMS

SCALE: 1/4" = 1'-0"

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 10/31/13

HARRIMAN

AUBURN PORTLAND MANCHESTER

GOULD RESTAURANT

414 FORE STREET
PORTLAND, ME 04101

Harriman Project No.	12752

Key Plan

Proj North

Issues and Revisions

Mark	Date	Description
--	09-23-13	RE-ISSUED FOR CONSTRUCTION

STATE OF MAINE
JOHN W. TARR
No. 7700
LICENSED
PROFESSIONAL ENGINEER

Drawing Scales
1/4" = 1'-0"

0 2' 4' 6'

PA / PE: JWT

Drawn By: DSH

© 2013
Harriman Associates

ELECTRICAL
PART PLANS
POWER & SYSTEMS

E20.3