



FOURTH FLOOR FIRE ALARM PLAN
 SCALE: 1/8"=1'-0"

SHEET NOTES:

- ◇ LOCATE DETECTORS AT TOP OF ELEVATOR HOISTWAY.
- ◇ PROVIDE HEAT DETECTOR(S) WITHIN 24" OF EACH SPRINKLER HEAD IN THE ELEVATOR CONTROL ROOM AND HOISTWAY(S). HEAT DETECTORS SHALL HAVE A LOWER TEMPERATURE RATING THAN THE SPRINKLERS IN THE AREA AND BE MONITORED FOR INTEGRITY.

RESERVED FOR CITY STAMP

| REVISION | DESCRIPTION | DATE |
|----------|------------------------------|-----------|
| 0 | ISSUED FOR REVIEW & APPROVAL | 4/2/2015 |
| 1 | REVISED PER CLIENT REVIEW | 4/10/2015 |
| | | |
| | | |
| | | |

CUNNINGHAM
Security Systems
 10 Princes Point Road, Yarmouth, Maine 04096
 Office: 207.846.3350 • Fax: 207.846.6080

6 CITY CENTER
PORTLAND, MAINE 04101
FOURTH FLOOR FIRE ALARM PLAN

| | | | | |
|-----------------------------------|---|------------------|---------------|---------------------|
| DRAWN UNICAD JOB #15211 JPB | CHECKED WYNNE B. HAWES NCSET IV 90496 | DATE 4/2/2015 | REVISION 1 | SCALE 1/8"=1'-0" |
|-----------------------------------|---|------------------|---------------|---------------------|

5700 BANGOR
 574 W. 40TH ST.
 PORTLAND, ME 04103
 OFFICE: 207.846.6080
 WWW.CUNNINGHAM.COM

UNICAD
 Inc.
 Fire Alarm Design & Drafting Services

FA-6