Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/09/17

Portland Maine Yes. Google's good here.

Laurie Leader <lrl@portlandmaine

Re: BP#2017-00344 6 City Center - Plan review comments

1 message

Michael R. Charek, AIA <mcharek@charekarchitects.com> Mon, May 8, 2017 at 5:31 PM
To: Laurie Leader <LRL@portlandmaine.gov>

Laurie,

Thank you for your comments. A revised plan is attached. Please note that under IBC 2009, no separation is required between M, B, or S1 occupancies. However, a one-hour separation is required under NFPA 101 2009. I revised both code tables to make that clear.

Please let me know if you need anything else.

Michael R. Charek, AIA
Michael Charek Architects
25 Hartley Street
Portland, ME 04103
207-761-0556

On May 8, 2017, at 2:46 PM, Laurie Leader <LRL@portlandmaine.gov> wrote:

Michael,

Attached are the plan review comments for the above referenced building permit.

Please send all revisions to this (my) email and please note that the pdf file name shall be exactly as the original, refer to the name of the attached files. Our Eplan program will automatically assign a version to the revised plans.

Let me know if you have any questions,

Thanks,
Laurie

--
Laurie Leader
Plan Review/Code Enforcement
City of Portland, Maine
Inspections Division
389 Congress Street
Portland, ME 04101

P: 207-874-8714
F: 207-874-8716
E: lrl@portlandmaine.gov

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/09/17

city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.<A2 Life Safety Plan.pdf>

A2 Life Safety Plan.pdf
87K