

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
SIX CITY CENTER LLC

Located at
6 CITY CTR

PERMIT ID: 2018-00075 ISSUE DATE: 02/22/2018 CBL: 032 P004001

has permission to **Change of use from art gallery to nail salon. Renovations to fit up space.**
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

Fire Official

/s/ Brian Stephens

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Personal services

Building Inspections

Use Group: B **Type:** 3B
Business - Beauty Shop (H&E Paint
Nail Bar)
Occupant Load = 14
Sprinkled: NFPA 13
1st Flr (Free St. Side)
MUBEC/IBC-2009

Fire Department

Classification:
Business
ENTIRE
NFPA 101 CH 39

PERMIT ID: 2018-00075

Located at: 6 CITY CTR

CBL: 032 P004001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Certificate of Occupancy/Final Inspection
Close-in Plumbing/Framing w/Fire & Draft Stopping
Electrical Close-in w/Fire & Draftstopping
Final - Electric
Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2018-00075	Date Applied For: 01/18/2018	CBL: 032 P004001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Personal services - Nail salon		Proposed Project Description: Change of use from art gallery to nail salon. Renovations to fit up space.		
Dept: Historic Status: Approved w/Conditions Reviewer: Robert Wiener Approval Date: 02/21/2018 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) No exterior alterations are approved with this permit, including but not limited to doors, windows, venting, mechanical equipment, signage, lighting, masonry.				
Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 01/26/2018 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) This permit is being approved on the basis of plans and documents submitted. Any deviations shall require a separate approval before starting that work. 2) This permit is approving interior work only. Any exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District. 3) Separate permits shall be required for any new signage. 4) This unit shall remain personal services (nail salon). Any change of use or addition of new uses shall require a separate permit application for review and approval.				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Brian Stephens Approval Date: 02/13/2018 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) The issuance of this permit shall not be construed to be a permit for, or approval of, any violations of any of the provisions of the building code or of any other ordinance of this jurisdiction. 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. 3) Construction shall be in compliance with the requirements of the IBC 2009, MUBEC and ADA standards. 4) Per IBC Sec. 3401.3 for existing buildings and dwelling units, compliance with smoke, carbon monoxide, fire protection and safety systems and devices shall be per City Ordinance Chapter 10 and NFPA 101 5) All existing fire separation partitions, barriers and horizontal assemblies at adjacent occupancies or dwelling units shall be maintain for rating and continuity. Additional materials may need to be added for compliance. 6) All penetrations shall maintain the fire resistance rating of walls and ceilings with approved firestop materials, including electrical fixtures and exhaust vents per IBC Sec. 713 and IRC Sec. R302.4 7) The addition of plumbing fixtures, including water lines, drainage and vent piping shall be installed in compliance with the UPC 2015 code. 8) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 9) Ventilation of this space is required per ASHRAE 62.2 or 62.1, 2007 edition. 10 This project includes alterations that Maine state law requires for compliance with the 2010 ADA Standards for Accessible Design.				

PERMIT ID: 2018-00075

Located at: 6 CITY CTR

CBL: 032 P004001

Dept: Engineering DPS **Status:** Not Applicable **Reviewer:** Benjamin Pearson **Approval Date:** 01/26/2018

Note: **Ok to Issue:** ☒

Conditions:

- 1) This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 874-8801.

Dept: Fire **Status:** Approved w/Conditions **Reviewer:** Jason Grant **Approval Date:** 02/14/2018

Note: **Ok to Issue:** ☒

Conditions:

- 1) All construction shall comply with City Code, Chapter 10.
All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43 and other applicable chapters
All construction shall comply with 2009 NFPA 1, Fire Code.
This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4).
All means of egress to remain accessible at all times.
If applicable, all outstanding code violations shall be corrected prior to final inspection.