

Inspection Services
Michael J. Nugent
Manager

Department of Urban Development
Joseph E. Gray, Jr.
Director



CITY OF PORTLAND

May 15, 2000

Ron Nicholas
% Steve Flynn
P. O. Box 2353
W. Scarborough, ME 04074

RE: 428 Fore St.
CBL: 032-R-001

Dear Mr. Nicholas:

This is to verify that the Interior stairway enclosure at 428 Fore St. needs to comply with the BOCA 1996 Building Code 1014.11 regarding fire separation assemblies.

Attached is the referenced code.

Please be advised that any previous information given regarding a sprinkler system reduction in rating factor is considered a misrepresentation of fact. We apologize for any inconvenience this may have caused. Please feel free to contact me Jeanie Bourke @ 874-8715 if you have any questions regarding this matter.

Sincerely,

Jeanie Bourke
Code Enforcement Officer
/jmb