

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that
DREAM PORT 3 LLC

Located at
434 FORE ST (43 Wharf Street)

PERMIT ID: 2015-00829 **ISSUE DATE:** 05/14/2015 **CBL:** 032 R004001

has permission to **Alterations - For the removal of one (1), non-load bearing wall and to extend the existing bar (new bar layout).**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Framing Only

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-00829	Date Applied For: 04/22/2015	CBL: 032 R004001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Retail & Personal Service		Proposed Project Description: Alterations - For the removal of one (1), non-load bearing wall and to extend the existing bar (new bar layout).		
Dept: Historic	Status: Approved w/Conditions	Reviewer: Deborah Andrews	Approval Date: 05/14/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Any proposed new signage and/or lighting is subject to separate review and approval by Historic Preservation staff.				
2) Approved with the understanding that the scope of work includes no exterior alterations.				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 04/28/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This permit approves interior work only.				
2) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 04/28/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 05/14/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) All outstanding code violations shall be corrected prior to final inspection.				
2) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.				
3) Shall comply with NFPA 101, Chapter 37, Existing Mercantile Occupancies.				
4) Shall meet the requirements of 2009 NFPA 1 Fire Code.				
5) All construction shall comply with City Code Chapter 10.				