

# interoffice

## MEMORANDUM

---

TO: Lt. MacDougal

CC: Arthur Rowe, CEO

FROM: Nadine Beth Williamson

RE: The Better End at 446 Fore Street CBL: 032-R-008

Date: September 30, 1999

The following life safety violations were noted during an FSE inspection on September 29, 1999.

1. Exit light on second floor inoperative
2. Blocked rear exit
3. Propane tank in cellar
4. Ragged handrail from second to first floor, top of stairs

Thank you for your attention to this matter.

from the desk of..  
Nadine Beth Williamson  
OFFICE MANAGER  
INSPECTIONS

X 8701  
Fax:874-8716