

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

ADRIENNE-JANE INCORPORATED

Located at

4 MOULTON ST (177 Commercial St.)

PERMIT ID: 2014-02528

ISSUE DATE: 12/03/2014

CBL: 032 T004001

has permission to **Construct a storage area with concrete pad for soda concentrate storage in basement for Bill's Pizza**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

Fire Official

/s/ Jeanie Bourke

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

restaurant & retail 1st floor - offices above

Building Inspections

Use Group: A-2

Type: 3B

Restaurant - Bill's Pizza

First Floor

MUBEC/IBC

Fire Department

PERMIT ID: 2014-02528

Located at: 4 MOULTON ST (177

CBL: 032 T004001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-02528	Date Applied For: 10/29/2014	CBL: 032 T004001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Restaurant & retail 1st floor - offices above		Proposed Project Description: Construct a storage area with concrete pad for soda concentrate storage in basement for Bill's Pizza		
Dept: Historic		Status: Approved w/Conditions	Reviewer: Robert Wiener	Approval Date: 12/01/2014
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) No exterior alterations are approved with this permit. Any exterior work must be reviewed and approved separately prior to construction.		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 11/17/2014
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.		
Dept: Building		Status: Approved w/Conditions	Reviewer: Jeanie Bourke	Approval Date: 12/02/2014
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. 2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.		
Dept: Fire		Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 11/21/2014
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) All construction shall comply with City Code Chapter 10.		