

# 354483

Portland, Maine



Yes. Life's good here.

December 10, 2015

One Dana Llc

Po Box 4894

Portland, ME 04112

CBL: 032 U004001

Located at 0195 COMMERCIAL ST

#### NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at [www.portlandmaine.gov](http://www.portlandmaine.gov).

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

*A/C Keith Jantson*

Portland Fire Department

Fire Prevention Bureau

**CITY OF PORTLAND  
PORTLAND FIRE DEPARTMENT**

380 Congress Street  
Portland, Maine 04101

**Inspection Violations**

<b>Owner/Manager</b> One Dana Llc		<b>Inspector</b> Curtis Magnuson		<b>Inspection Date</b> 12/9/2015
<b>Location</b> 0195 COMMERCIAL ST	<b>CBL</b> 032 U004001	<b>Status</b> Failed		<b>Inspection Type</b> Fire Company-FP Routine Inspec

<b>Code</b>	<b>Int/Ext</b>	<b>Floor</b>	<b>Unit No.</b>	<b>Area</b>	<b>Compliance Date</b>
-------------	----------------	--------------	-----------------	-------------	------------------------

1) 10.002

**Violation:** NFPA 10- 7.1.1 FIRE EXTINGUISHERS NEED ANNUAL SERVICE; THE OWNER OR DESIGNATED AGENT OR OCCUPANT OF A PROPERTY IN WHICH FIRE EXTINGUISHERS ARE LOCATED SHALL BE RESPONSIBLE FOR INSPECTION, MAINTENANCE, AND RECHARGING.

**Notes:** ALSO HANG BY THE FRONT DOOR

2) 80.28

**Violation:** NFPA 101- 7.5.1.1 EXIT OBSTRUCTED; Where exits are not immediately accessible from an open floor area, continuous passageways, aisles, or corridors leading directly to every exit shall be maintained and shall be arranged to provide access for each occupant to not less than two exits by separate ways of travel, unless otherwise provided in 7.5.1.1.3 and 7.5.1.1.4.

**Notes:** SECOND EXIT ON THE DANA STREET SIDE IS BLOCKED ON THE EXTERIOR WITH TRASH AND RECYCLING.

**Comments:**

STATE OF MAINE

DISTRICT COURT  
Location: Portland  
Docket No.

CITY OF PORTLAND and body politic and  
Corporate, located in the County of  
Cumberland and State of Maine,

Plaintiff,

**FIRE PREVENTION AND PROTECTION  
CODE VIOLATION**

**(M.R. CIV. P. 80H AND 80k)**


v.

One Dana LLC  
Defendant

SUMMONS NUMBER: 354483

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 02/08/2016. Please contact Tori Ross in Fire Prevention at (207)-874-8400 or via e-mail at [meservev@portlandmaine.gov](mailto:meservev@portlandmaine.gov) to set up an in-person meeting to meet with somebody in the Fire Prevention Bureau to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 02/08/2016.

Dated: 12/15/15

  
Adam R. Lee, Esq. Bar No. 4143  
Associate Corporation Counsel  
City of Portland  
389 Congress St  
Portland, ME 04101  
207-874-8480