



NOTE: ANY DUCTWORK FOUND NOT MEETING CLEARANCE TO COMBUSTIBLES WILL BE WRAPPED w/ ZERO CLEARANCE DUCT WRAP
 ALL NEW DUCTWORK TO BE 16 GA BLACK IRON

SEIDMAN BROS. INC.
 25 SIXTH STREET
 CHELSEA, MA 02150

SCALE 1/4" = 1'
 DRN BY JACK SEIDMAN
 DATE FEB 21, 2012

JOB LOCATION
 RECONFIGURATION OF EXHAUST SYSTEMS FOR
 VIGNOLIA REST
 10 DANA STREET
 PORTLAND ME 04101
 207-347-6154