

GENERAL NOTES

- A. ALL WIRING SHALL BE IN CONDUIT, EMT OR RIGID FLEXIBLE CONDUIT MAY ONLY BE USED FOR FINAL CONNECTIONS FROM OUTLET BOXES TO LIGHT FIXTURES, MOTORS, APPLIANCES, ETC. MAXIMUM LENGTH 6 FEET. NO BX, ROMEX, ARMORED CABLE, ETC. ALLOWED.
- B. IT'S THE ELECTRICAL CONTRACTORS RESPONSIBILITY TO BALANCE ALL CIRCUITS BETWEEN THE PHASES OF THE SYSTEM, REGARDLESS OF
- CIRCUITS INDICATED.

 C. IN PUBLIC AREAS BATTERY PACKS FOR EXIT AND EMERGENCY LIGHTS MUST BE REMOTE OR RECESSED. PAINT EXPOSED SURFACE TO MATCH ADJACENT FINISH.
- D. ALL PENETRATIONS IN FIRE RATED WALL ASSEMBLIES SHALL BE SEALED WITH UL LISTED FIRE STOPPING MATERIAL.
- WITH UL LISTED FIRE STOPPING MATERIAL.

 E. GENERAL CONTRACTOR SHALL LOCATE ALL EXISTING POST—TENSIONING STRANDS IN EITHER DIRECTION PRIOR TO INSTALL OF ANCHORS. IT IS

IMPERATIVE THAT NO STRANDS BE DAMAGED BY THE USE OF ANCHORS.
PENETRATION OF ANCHORS INTO SLAB SHALL NOT EXCEED 1 1/2".

ELEVATION FRANCHISE VENTURES
4100 NORTH FAIRFAX DR. STE 730

KEYED NOTES

- 1. 15' DAY LIGHTING ZONE EASEMENT PER ENERGY CODE.
- 2. NIGHT LIGHTS (NL) TO BE UNSWITCHED FOR NIGHT LIGHTING.
- 3. SWITCH BANK. LABEL SWITCHES PER AREA SERVED.
- 4. WATTSTOPPER PW-100 OR EQUAL. WALL MOUNT PASSIVE INFRARED OCCUPANCY SENSOR SWITCH.
- 5. PROVIDE DUAL LEVEL SWITCHING FOR A 50% REDUCTION IN LIGHTING (ALTERNATE FIXTURES) WITHIN KITCHEN AREA. REFER TO 1/E2.2.
- 6. HOOD LIGHTS FURNISHED & INSTALLED WITH HOOD. CONNECT HOOD LIGHTS TO CIRCUIT B-22.
- 7. LIGHT FIXTURES WITHIN COOLER/FREEZER ARE FURNISHED BY VENDOR,
- 8. CIRCUIT EXHAUST FANS TO RESTROOM LIGHTING. PROVIDE ALL
- 9. FIXTURE DESIGNATED WITH 'EM' SHALL BE PROVIDED WITH A 90 MINUTE EMERGENCY BATTERY PACK.
- 10. EXISTING LIGHT FIXTURE TO REMAIN. CLEAN, RE-LAMP AND RE-BALLAST FIXTURE.
- 11. TO TRACK FIXTURE ON UPPER LEVEL. REFER TO SHEET E1.1 FOR
- CONTINUATION.
- 12. EXISTING LIGHT FIXTURE TO REMAIN. CLEAN, RE-LAMP AND RE-BALLAST FIXTURE.

BRIAN E.
CHANDLER
No. 12/19

BRIAN EDWARD

E-MAIL bchandler@idstudio4.com

1431 GREENWAY DRIVE

SUITE 510

IRVING, TX 75038

ARLINGTON, VA 22203 703.243.7894

www.elevationburger.com

PHONE 972.870.1288

11/18/2013

PORTLAND, ME 04101
CLIENT: BETTER BURGER



DATE DESCRIPTION

11/18/13 PERMIT ISSUE

DATE DESCRIPTION

SHEET TITLE

FIRST FLOOR LIGHTING PLAN

SHEET NUMBI

E1.0

JECT NUMBER:

EVB130001