

LIGHT FIXTURE SCHEDULE

LAMPS

(3) 32WT8

(3) 32WT8

(3) 32WT8

(3) 32WT8

(3) 32WT8

FLUORESCENT

FLUORESCENT

(2) F31T8SP41U6

(2) F31T8SP41U6

F26TBX841AECO-26W

F26TBX841AECO-26W

(1) 12.5W LED

(1) 27W GU24

(1) LED

17P38S9301/25

(1) F28T8XL842/ECO

(1) F28T8XL842/ECO | -

RECESSED GRID TROFFER WITH PARABOLIC LENS

FIXTURES LOCATED IN KITCHEN AREA SHALL BE PROVIDED WITH TUBE PROTECTORS AND 90 MINUTE

PROVIDE WITH CLEAR LENS AND WHITE FLANGE.

PROVIDE WITH CLEAR LENS AND WHITE FLANGE.

@ 9'-2" AFF TO BOTTOM OF FIXTURE

(1) 15W SPLP PAR30 | PROVIDE WITH NATURAL FINISH AND PROVIDE PAR 30

PROVIDE WITH NATURAL FINISH

(1) F26TBX841/AECO | PROVIDE WITH STAINLESS STEEL FINISH; PROVIDE

UL LISTED FOR WET LOCATION

LEAD-CALCIUM BATTERY

PROVIDE WITH 6 VOLT MAINTENANCE FREE

FIXTURE

PROVIDE SELF BALLASTED LAMP - INSTALL FIXTURE

PROVIDE WITH JUNO SILVER TRACK ACCESSORIES AS

REQUIRED. INSTALL AT 10'-0" AFF IN EXPOSED

CEILING U.N.O. SEE MOUNTING DETAIL A4/A310

LAMP AND INSTALL AT 7'-4" AFF TO CENTER OF

PROVIDE WITH CLEAR REFLECTOR AND WHITE FLANGE.

EMERGENCY BATTERY PACK

FLUORESCENT

LUORESCENT

LUORESCENT

TYPE DESCRIPTION

FLUORESCENT 2'X4' LAY-IN TYPE LENSED TROFFER

FLUORESCENT 2'X4' LAY-IN TYPE LOUVERED TROFFER

FLUORESCENT 2'X4' LAY-IN TYPE SURFACE MOUNTED

FLUORESCENT 2'X2' LAY-IN TYPE LENSED TROFFER

FLUORESCENT 2'X2' LAY-IN TYPE LENSED TROFFER

B2 DAY-BRITE LIGHTING #2LP3GS231U1-44W-UNV-EB10I-EM

6" VERTICAL CFL DOWNLIGHT OPEN REFLECTOR

6" VERTICAL CFL DOWNLIGHT LENSED REFLECTOR

HALO #H7T HOUSEING WITH CREE LIGHT LED LR6

TECH LIGHTING #700DMISCI303-IN WITH JUNO T3 ISL

LIGHITNG TRACK 4 FT. AND 8 FT. NATURAL ALUMINUM

INDY #C6V-126/42T/C600LC-CL-CG-WH

FLUORESCENT COBALT BLUE PENDANT

FLUORESCENT TRACK LIGHTING HEAD

HILITE #H-43205-B-101FR-23W-MAXLBL

LIGHTOLIER #ST4WA232UNV-CA-120

LIGHTOLIER #XPIGVA232UNVHI-CUL

EXITRONIX #VR2-V10H-WD

COOPER LIGHTING-SURE LITES #AP2SQ

EM

FLUORESCENT 4' ENCLOSED SURFACE MOUNT

FLUORESCENT 1'X4' LAY-IN TYPE - LENSED

UNIT AND LED DIRECTIONAL SIGN, SURFACE MOUNT COOPER LIGHTING-SURE LITES #AP70RWHDHSQ

COMBINATION BATTERY OPERATED EMERGENCY LIGHTING INTEGRAL

REMOTE EMERGENCY LIGHTING HEAD, SURFACE MOUNT INTEGRAL

BATTERY OPERATED EMERGENCY LIGHTING UNIT SURFACE INTEGRAL MOUNT

B2 DAY-BRITE LIGHTING #2TG8231U6-PA3-UNV-EB10I

2EP3GX-332S3610/040-UNV-AD-LO-P3P32SC-U

SAME AS TYPE 'A' EXCEPT WITH A 90 MINUTE

DAY-BRITE LIGHTING #2TG8332-PA3-UNV-EB101

SAME AS TYPE 'A' EXCEPT WITH A 90 MINUTE

EMERGENCY BATTERY PACK

COOPER LIGHTING - METALUX

EMERGENCY BATTERY PACK

LIGHTOLIER #BE2W-432-UNV-H1

INDY #C6V-126/42T/C600CLWH

6" LED RECESSED DOWNLIGHT

JUNO CIRCUIT TRACK SYSTEM

LED TRACK LIGHTING HEAD

FLUORESCENT WALL SCONCE

TRACK ADAPTOR.

4'=T4NA, 8'=T8NA

JUNO #T363-NA

JUNO #T368-NA

LENSED TROFFER

**GENERAL NOTES** 

- A. ALL WIRING SHALL BE IN CONDUIT, EMT OR RIGID FLEXIBLE CONDUIT MAY ONLY BE USED FOR FINAL CONNECTIONS FROM OUTLET BOXES TO LIGHT FIXTURES, MOTORS, APPLIANCES, ETC. MAXIMUM LENGTH 6 FEET. NO BX. ROMEX, ARMORED CABLE, ETC. ALLOWED.
- B. IT'S THE ELECTRICAL CONTRACTORS RESPONSIBILITY TO BALANCE ALL CIRCUITS BETWEEN THE PHASES OF THE SYSTEM, REGARDLESS OF
- CIRCUITS INDICATED. IN PUBLIC AREAS BATTERY PACKS FOR EXIT AND EMERGENCY LIGHTS MUST BE REMOTE OR RECESSED. PAINT EXPOSED SURFACE TO MATCH
- . ALL PENETRATIONS IN FIRE RATED WALL ASSEMBLIES SHALL BE SEALED WITH UL LISTED FIRE STOPPING MATERIAL.
- E. GENERAL CONTRACTOR SHALL LOCATE ALL EXISTING POST—TENSIONING STRANDS IN EITHER DIRECTION PRIOR TO INSTALL OF ANCHORS. IT IS

IMPERATIVE THAT NO STRANDS BE DAMAGED BY THE USE OF ANCHORS. PENETRATION OF ANCHORS INTO SLAB SHALL NOT EXCEED 1 1/2".

**KEYED NOTES** 

- EXISTING RAIL LIGHTING TO REMAIN. IF FOUND TO BE FAULTY, REPLACE WITH EXACT FIXTURE.
- 2. TO LOWER LEVEL LIGHTING.

ADJACENT FINISH.

3. EXISTING EXTERIOR WALL SCONCES TO REMAIN. CLEAN AND RE-LAMP FIXTURE.

**BRIAN EDWARD** 

E-MAIL bchandler@idstudio4.com

**ELEVATION FRANCHISE VENTURES** 

4100 NORTH FAIRFAX DR. STE 730

ARLINGTON, VA 22203 703.243.7894


www.elevationburger.com

1431 GREENWAY DRIVE

PHONE 972.870.1288

SUITE 510 IRVING, TX 75038

11/18/2013



11/10/13		I LINWII 1000L	
$\overline{Z}$	DATE		DESCRIPTION

SECOND FLOOR LIGHTING PLAN

SHEET NUMBER:

EVB130001

SECOND FLOOR LIGHTING PLAN