Inspections Division
Date: 01/06/14

December 26, 2013

City of Portland
Planning & Urban Development Dept. / Inspection Division
BP#2013-02610

RE: Elevation Burger
205 Commercial
Commercial Plan Review Comments

Jeanie Bourke,

This letter is the written response to your initial review comments received December 19, 2013.

1. **Comment:** Please correct the following: Electrical Code 2011, Mechanical: BOCA Mechanical 1993/ ASHRAE 62.1. Plumbing 2009 Uniform. Occupancy A-2 Restaurant.
   Response: Title sheet has been revised.

2. **Comment:** Trap Arm Length: Justify trap arm length in excess of 6' per UPC Table 10-1 and connection to SW line upstream of the floor drain per Sec 704.3.
   Response: Floor sink trap arm has been shortened, and moved accordingly

3. **Comment:** Direct Connection to SW Pipe: Provide direct connection to the plumbing waste line, in lieu of a floor sink, per UPC Sec 704.3. Connection of the sink to the SW line per the same section on the sewer side relation to the floor drain.
   Response: Floor drain has been rerouted to be vented prior to connecting to sanitary system.

Feel free to contact our office should you have any questions or follow up for additional information.

Best Regards,

Tania Inigo
Project Manager
972.870.1288