



© 2018 RYAN SENATORE ARCHITECTURE

DELI FIT-UP  
 UNION STREET  
 PORTLAND, MAINE



RYAN SENATORE  
 ARCHITECTURE  
 565 CONGRESS STREET  
 PORTLAND, MAINE 04101  
 207-650-6414  
 senatorearchitecture.com

CONSULTANTS:

REVISIONS:

DATE: 20 FEBRUARY 2018

PROJECT No. 1778

DRAWN BY: RRT, RJS, JPF

CHECKED BY: RJS

SCALE: AS NOTED

SHEET TITLE:  
 WALL  
 ASSEMBLIES

A0-1

GRAPHIC DEPICTION		DESCRIPTION											
		- EXISTING WALL - 2x6 WOOD STUDS AT 16" O.C. - 3-1/2" SOUND BATT INSULATION - LAYER OF 5/8" MOISTURE RESISTANT GWB											
		<table border="1"> <thead> <tr> <th>TYPE</th> <th>FIRE RATING</th> <th>UL NUMBER</th> <th>STC RATING</th> <th>IIC RATING</th> </tr> </thead> <tbody> <tr> <td>NC</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> </tbody> </table>				TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING	NC	N/A	N/A
TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING									
NC	N/A	N/A	N/A	N/A									

GRAPHIC DEPICTION		DESCRIPTION											
		- REFRIGERATED ROOM ASSEMBLY TO MATCH ADJACENT EXISTING - LAYER OF 5/8" GWB - 2x4 WOOD STUDS AT 24" O.C. - 3-1/2" SOUND BATT INSULATION - LAYER OF TYPE 'X' 5/8" GWB											
		<table border="1"> <thead> <tr> <th>TYPE</th> <th>FIRE RATING</th> <th>UL NUMBER</th> <th>STC RATING</th> <th>IIC RATING</th> </tr> </thead> <tbody> <tr> <td>NB</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> </tbody> </table>				TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING	NB	N/A	N/A
TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING									
NB	N/A	N/A	N/A	N/A									

GRAPHIC DEPICTION		DESCRIPTION											
		- LAYER OF TYPE 'X' 5/8" GWB - 2x6 WOOD STUDS AT 16" O.C. - 5-1/2" MINERAL WOOL / SOUND ATTENUATION FIRE BATT INSULATION - LAYER OF TYPE 'X' 5/8" GWB											
		<table border="1"> <thead> <tr> <th>TYPE</th> <th>FIRE RATING</th> <th>UL NUMBER</th> <th>STC RATING</th> <th>IIC RATING</th> </tr> </thead> <tbody> <tr> <td>1A</td> <td>1 HR</td> <td>U301</td> <td>35-39</td> <td>N/A</td> </tr> </tbody> </table>				TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING	1A	1 HR	U301
TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING									
1A	1 HR	U301	35-39	N/A									

GRAPHIC DEPICTION		DESCRIPTION											
		- LAYER OF 5/8" GWB - 2x4 WOOD STUDS AT 24" O.C. - 3-1/2" SOUND BATT INSULATION - LAYER OF 5/8" GWB											
		<table border="1"> <thead> <tr> <th>TYPE</th> <th>FIRE RATING</th> <th>UL NUMBER</th> <th>STC RATING</th> <th>IIC RATING</th> </tr> </thead> <tbody> <tr> <td>NA</td> <td>N/A</td> <td>N/A</td> <td>35-39</td> <td>N/A</td> </tr> </tbody> </table>				TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING	NA	N/A	N/A
TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING									
NA	N/A	N/A	35-39	N/A									

- WALL TYPE NOTES**
- 1.) FIRE RATED WALLS TO EXTEND UP TO DECKING ABOVE THROUGH THE FLOOR / CEILING ASSEMBLY.
  - 2.) INSTALL WATER RESISTANT GYPSUM WALLBOARD IN ALL RESTROOMS AND TOILET ROOM WALLS AND CEILINGS, AND AT ANY WALL WITH PLUMBING FIXTURES
  - 3.) WHEN TWO ADJACENT WALL TYPES HAVE DIFFERING NUMBERS OF LAYERS OF GWB, THE FINISHED FACE OF GWB MUST FORM ONE CONTINUOUS PLANE, ADJUST STUD PLANE LOCATION AS REQUIRED TO ACHIEVE THE CONTINUOUS PLANE
  - 4.) HOLD BOTTOM OF GWB UP 1/2" FROM CONCRETE, PROVIDE SEALANT AT JOINT.
  - 5.) ALL WALL TYPES WITH AN INSULATION COMPONENT TO BE ACOUSTICALLY SEALED
  - 6.) PROVIDE ACOUSTICAL SEALANT AROUND ALL PENETRATING ELEMENTS IN WALLS AND CEILINGS (ELECTRICAL BOXES, DUCTS, PIPES, ETC)
  - 7.) PROVIDE DIAGONAL BRACING UP TO DECK ABOVE AT ALL INTERIOR PARTITIONS THAT DO NOT GO UP TO DECK ABOVE FOR STIFFNESS AS REQUIRED