

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT

This is to certify that  
MAINE STATE SECURITY  
98 COMPANY RD  
DAYTON, ME 04005

For installation at  
34 WHARF ST (10 DANA ST)  
CINQUE TERRA & VIGNOLA'S

Job ID: 2011-12-2992-ALTCOMM

CBL: 032- V-016-001

has permission to renovate a supervised fire alarm system

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be

  
Fire Prevention Officer

  
Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
PENALTY FOR REMOVING THIS CARD

## BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

### **Final Fire**

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.



# PORTLAND MAINE

*Strengthening a Remarkable City, Building a Community for Life* • [www.portlandmaine.gov](http://www.portlandmaine.gov)

Director of Planning and Urban Development  
Penny St. Louis

**Job ID: 2011-12-2992-ALTCOMM**  
**renovate a supervised fire alarm system**

**For installation at:**  
**34 WHARF ST (10 DANA ST)**  
**CINQUE TERRA & VIGNOLA'S**

**CBL: 032- V-016-001**

## **Conditions of Approval:**

### **Fire**

The fire alarm system shall comply with the City of Portland Standard for Signaling Systems for the Protection of Life and Property. All fire alarm installation and servicing companies shall have a Certificate of Fitness from the Fire Department.

In field installation shall be installed per code as conditions dictate.

Records cabinet, FACP, annunciator(s), and pull stations shall be keyed alike.

Central Station monitoring for addressable fire alarm systems shall be by point.

All fire alarm records required by NFPA 72 should be stored in an approved cabinet located at the FACP labeled "FIRE ALARM RECORDS".

Installation of a Fire Alarm system requires a Knox Box to be installed per city ordinance.

The fire alarm system shall be certified by a master fire alarm company and have a new fire alarm inspection sticker.

System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.

Fire Alarm system shall be maintained. If system is to be off line over 4 hours a fire watch shall be in place. Dispatch notification required 874-8576.

**City of Portland, Maine - Building or Use Permit Application**

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

Job No: 2011-12-2992-ALTCOMM 2012-40932 FAFS	Date Applied: 02/16/2012	CBL: 032- V-016-001	
Location of Construction: 10 DANA STREET	Owner Name: 10 DANA STREET LLC	Owner Address: 10 DANA ST. STE 300 PORTLAND, ME 04101	Phone:
Business Name: Vignola's Restaurant	Contractor Name: Maine State Security	Contractor Address: 1308 New Country Rd, Dayton, ME 04005	Phone: (207) 247-4371
Lessee/Buyer's Name:	Phone:	Permit Type: FAFS- Fire alarm	Zone: B-3
Past Use: Restaurant	Proposed Use: Same: Restaurant - to install a fire alarm	Cost of Work: \$5,000.00	CEO District:
		Fire Dept: <input checked="" type="checkbox"/> Approved w/ conditions <input type="checkbox"/> Denied <input type="checkbox"/> N/A	Inspection: Use Group: Type:
		Signature: <i>[Signature]</i> (53)	Signature:
Proposed Project Description: install fire alarm		Pedestrian Activities District (P.A.D.)	

Permit Taken By: Brad	<b>Zoning Approval</b>		
<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building Permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.</p>	<b>Special Zone or Reviews</b> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetlands <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan  <input type="checkbox"/> Maj <input type="checkbox"/> Min <input type="checkbox"/> MM Date: <i>OK 2/16/12</i>	<b>Zoning Appeal</b> <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	<b>Historic Preservation</b> <input checked="" type="checkbox"/> Within <input type="checkbox"/> Not in Dist or Landmark <input type="checkbox"/> Does not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: <i>ANY Exterior work requires SA Separate Review and Approval</i>
	<b>CERTIFICATION</b>		

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE



# Fire Alarm Permit

*Child  
2012-40932*

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: 10 Dana Street CBL: 032-V-016-001

Exact location: (within structure) Vignola's Resturant

Type of occupancy(s) (NFPA & ICC): Small Assembly and general business

Building owner: 10 Dana Street LLC ~~GVP Properties LLC 207 Main St Ste 403~~

System Designer (point of contact): Wayne Haws Unicad Inc. 5794 w. 4600 S.Hooper, UT. 84315 ~~Lowell St, ME~~

Designer phone: 801-985-0410 E-mail: wayne@unicad.net

Installing contractor: Maine State Security Certificate of Fitness No: M1002

Contractor phone: 207-247-4371 E-mail: info@mainestatesecurity.com

This is a new application: YES  NO  New AES Master Box: YES  NO   
(Include Master Box approval form)

Amendment to an existing permit: YES  NO  Permit no: \_\_\_\_\_

**The following documents shall be provided with this application:**

- Floor plans •  Scope of Work •
- Wiring diagram •  11 1/2 x 17s
- Annunciator details  pdf copy (may be e-mailed)
- Input/ Output Matrix •  Designer qualifications •
- Equipment data sheets •  Battery/ voltage drop calcs
- Electrical Permit Pulled (check alarm/com)

COST OF WORK: 5000

PERMIT FEE: 70  
(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

**RECEIVED**  
**FEB 16 2012**  
Dept. of Building Inspections  
City of Portland

Master box approval only: YES  NO   
(If yes check *New AES Master Box* above)

**The designer shall be the responsible party for this application. Download a new copy of this application at [www.portlandmaine.gov/fire](http://www.portlandmaine.gov/fire) for every submittal. Submit all plans in electronic PDF in addition to readable 11 1/2 x 17s to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.**

Prior to acceptance of any fire alarm system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with the *City of Portland Technical Standard for Signaling Systems for the Protection of Life and Property*, available at [www.portlandmaine.gov/fire](http://www.portlandmaine.gov/fire).

Applicant signature: *David S. [Signature]* Date: 2/16/12

# Maine State Security Services

*A Division of L'Heureux Inc.*

1308 New County RD Dayton, ME 04005  
Tel: 207-247-4371  
Fax: 207-929-8484  
Email: info@mainestatesecurity.com

February 15, 2012

Portland Fire Prevention  
Lt. Ben Wallace  
380 Congress Street  
Portland, Me 04101

Re: 10 Dana Street

Scope of work: We intend to reconfigure and add devices to the existing fire alarm system that is serviced and monitored by Cunningham Security, Vignola's Restaurant is doing a renovation and taking in the side they have now with what was Cinque Terre, Bathrooms are moving and the strobes will follow to the new bathrooms, the Cinque Terre side did not have pull stations and they will be installed now (2), this side is also being sprinkled and will have its own flow switch that will be tied into the system, and any tamper the sprinkler company may add, The existing ansul system is moving and we will reconnect that, we will be adding an annunciator to the front of Vignola's and moving the horn strobe there now to inside the restaurant instead of in the vestibule, we will also be adding 4 addition horn strobes in the expansion area. All other devices are not being touched,

Please feel free to give me a call after reviewing the submittals if you have any questions.

Sincerely,



Chris L'Heureux  
President.



**NATIONAL INSTITUTE FOR CERTIFICATION  
IN ENGINEERING TECHNOLOGIES®**

*Providing Certification Programs Since 1961*

BE IT KNOWN THAT

**Wayne B. Haws**

IS HEREBY AWARDED CERTIFICATION AT

**LEVEL IV**

**IN FIRE PROTECTION ENGINEERING TECHNOLOGY  
FIRE ALARM SYSTEMS**

BASED UPON SUCCESSFUL DEMONSTRATION OF REQUISITE KNOWLEDGE,  
EXPERIENCE AND WORK PERFORMANCE AS SET FORTH BY THIS INSTITUTE.

Certification Valid through May 1, 2014

CERTIFICATION NUMBER 90496


A handwritten signature in cursive script, appearing to read "Arthur B. DeVot".

CHAIRMAN OF THE NICET BOARD OF GOVERNORS

A DIVISION OF THE NATIONAL SOCIETY OF PROFESSIONAL ENGINEERS

# 6160CR-2

COMMERCIAL FIRE ALPHA KEYPAD  
UL864 REV 9 LISTED



The 6160CR-2 is an addressable remote keypad intended for use in commercial fire applications with Honeywell's commercial fire control panels. The keys are continuously backlit for convenience and easy visibility. The LCD display

is backlit only when a key is depressed\*, or when the system is in alarm or trouble condition.

\*Note: The LCD may be programmed to remain on at all times (see panel instructions for details).

## FEATURES

- Four programmable function keys
- Built-in sounder
- Seven Status LEDs
  - Armed (Red)
  - Ready (Green)
  - Power (Green)
  - Fire Alarm (Red)
  - Silenced (Yellow)
  - Supervisory (Yellow)
  - Trouble (Yellow)
- Large easy-to-read display
- Red removable door
- Physical  
5.250" W x 7.437" H x 1.312" D

## SPECIFICATIONS

### Sounder

- High-quality speaker

### Electrical

- 45mA standby 160mA in alarm (sounder, back light and LED on)

### Compatibility

- Supports Control Panels
  - VISTA-32FB Rev 5 and higher
  - VISTA-128FBP Rev 4 and higher
  - VISTA-250FBP Rev 4 and higher

UL/CUL and residential Listed for commercial fire and burglary installations. To be employed with manufacturer's listed control units as indicated in the installation instructions.

*Product specifications subject to change.*

## ORDERING

**6160CR-2** Commercial Fire Alpha Keypad

For more information: [www.honeywell.com/security/hsc](http://www.honeywell.com/security/hsc)

### Automation and Control Solutions

Honeywell Security & Communications  
2 Corporate Center Dr. Suite 100  
Melville, NY 11747  
1.800.467.5875  
[www.honeywell.com](http://www.honeywell.com)

# Honeywell

L/6160CR2D/D  
September 2009  
© 2009 Honeywell International Inc.





# 5140MPS-1 / 5140MPS-2 Manual Pull Stations

## PRIMARY FEATURES

- ADA COMPLIANT
- KEY TEST OR ALLEN RESET
- KEYED TO ADEMCO CONTROLS
- STYLIZED HIGH TECH DESIGN
- ALUMINUM DIE CAST HOUSING
- TERMINAL BLOCK OR WIRE LEADS
- GOLD CONTACTS
- UL LISTED

## ■ GENERAL DESCRIPTION

Ademco's manual fire alarm stations are designed to be non-code single action devices for use in UL listed fire alarm applications. The attractive die-cast aluminum-alloy housing meets ADA pull requirements and has been tested at Underwriter's Laboratory.

For ADA compliance, manual stations must be mounted less than 48" above the floor for front wheelchair access and less than 54" above the floor for side wheelchair access.

A key reset feature on the 5140MPS-1 is designed for positive authorized resetting action. The key is designed to operate and match Ademco controls. The 5140MPS-1 utilizes a terminal block for secure terminations. The 5140MPS-2 is furnished with an Allen hex fitting and is equipped with wire leads.


Two alarm deterrent break tubes are supplied with each manual station; one tube is visible from the front, and the spare is stored in a compartment within the unit.

## ■ OPERATION

Pulling the handle down causes the manual stations to latch in the down position and to close the normally open switch. The handle is restored manually by using the key to unlock the station and pivot the station forward for resetting the pull handle to its normal position. The crush tube is then inserted in the cavity and the station assembly is then locked in the normal upright position.

## ■ CONSTRUCTION

The 5140MPS-1 and 5140MPS-2 manual stations are constructed of a durable die-cast aluminum-alloy and



provide a neat and distinctive appearance. The housing is finished in red with white raised lettering and the "T-bar" handle is white with raised red lettering for enhanced visibility. The units are adaptable to both surface and semi-flush mounting configurations.

## ■ MOUNTING

### SEMI-FLUSH MOUNT

Most semi-flush mount installations can be attached to a standard single-gang switch box using two 6-32 screws inserted through the slots that are centered on the unit's metal mounting plate.

### SURFACE MOUNT

Use Ademco Backbox model number 5140MPS-BB for surface mount installations. The Backbox has four pre-drilled mounting holes of 0.187 inch diameter and conduit knockouts. Secure the Backbox to a wall with screws of size 8 or smaller. After the Backbox is in place, attach the conduit.

The housing is locked by using a key or Allen wrench lock. Unlock the housing by turning the key clockwise and swinging down the front of the housing to make the sheet metal mounting plate accessible. Mount the metal plate to the Backbox using the four 1/4" long, 8-32 screws (supplied).

## ■ DIMENSIONS

4.75" H x 3.12" W x 2" D

**ADEMCO**

The Technology Leader


## ■ ORDERING INFORMATION

**5140MPS-1:** Manual Station  
Key Reset Test  
and Terminal Block

**5140MPS-2:** Manual Station  
Hex Allen Reset  
Test and Wire Leads

**5140MPS-BB:** Surface Backbox

## ■ WIRING DIAGRAM



## ARCHITECTURAL/ENGINEERING SPECIFICATIONS

Manual Fire Alarm Station Model 5140MPS-1 (5140MPS-2) shall be non-coded and include a break-type tube operated test-reset lock allowing testing with a key (Allen wrench). They shall be designed so that normal operation cannot be restored after an actual Fire Emergency Operation except by use of a key (Allen wrench). The key shall fit all standard Ademco controls.

An operated station shall automatically condition itself so as to be visually detected, as operated, at a mini-

imum distance of one hundred feet, front or side. Manual Stations shall be constructed of die cast aluminum alloy with clearly visible operating instructions provided on the cover. The word FIRE shall appear on the front of the stations in raised letters. Stations shall be suitable for surface mounting on matching Backbox, or semi-flush mounting on a standard single-gang box. Manual Stations shall be Underwriter's Laboratories Listed.



## Selectable-Output Horns, Strobes, and Horn Strobes

*SpectrAlert® Advance selectable-output horns, strobes, and horn strobes are rich with features guaranteed to cut installation times and maximize profits.*



**SPECTRAlert**  
**ADVANCE**  
from System Sensor

### Features

- Plug-in design with minimal intrusion into the back box
- Tamper-resistant construction
- Automatic selection of 12- or 24-volt operation at 15 and 15/75 candela
- Field-selectable candela settings on wall and ceiling units: 15, 15/75, 30, 75, 95, 110, 115, 135, 150, 177, and 185
- Horn rated at 88+ dBA at 16 volts
- Rotary switch for horn tone and three volume selections
- Universal mounting plate for wall and ceiling units
- Mounting plate shorting spring checks wiring continuity before device installation
- Electrically compatible with existing SpectrAlert products
- Compatible with MDL sync module

**The SpectrAlert Advance series** offers the most versatile and easy-to-use line of horns, strobes, and horn strobes in the industry. With white and red plastic housings, wall and ceiling mounting options, and plain and FIRE-printed devices, SpectrAlert Advance can meet virtually any application requirement.

Like the entire SpectrAlert Advance product line, horns, strobes, and horn strobes include a variety of features that increase their application versatility while simplifying installation. All devices feature plug-in designs with minimal intrusion into the back box, which make installations fast and foolproof while virtually eliminating costly and time-consuming ground faults. Furthermore, a universal mounting plate with an onboard shorting spring tests wiring continuity before the device is installed, protecting devices from damage.

In addition, field-selectable candela settings, automatic selection of 12- or 24-volt operation, and a rotary switch for horn tones with three volume selections enables installers to easily adapt devices to suit a wide range of application requirements.

### Agency Listings



S401<sup>1</sup> (chimes, horn strobes, horns)  
SS12 (strobes)



3023572



MEA452-05-E



7125-1653-186 (indoor strobes)  
7125-1653-188 (horn strobes,  
chime strobes)  
7135-1653-189 (horns, chimes)

# SpectrAlert Advance Specifications

## Architect/Engineer Specifications

### General

SpectrAlert Advance horns, strobes, and horn strobes shall mount to a standard 4 × 4 × 1½-inch back box, 4-inch octagon back box, or double-gang back box. Two-wire products shall also mount to a single-gang 2 × 4 × 1½-inch back box. A universal mounting plate shall be used for mounting ceiling and wall products. The notification appliance circuit wiring shall terminate at the universal mounting plate. Also, SpectrAlert Advance products, when used with the Sync-Circuit™ Module accessory, shall be powered from a non-coded notification appliance circuit output and shall operate on a nominal 12 or 24 volts. When used with the Sync-Circuit Module, 12-volt-rated notification appliance circuit outputs shall operate between 9 and 17.5 volts; 24-volt-rated notification appliance circuit outputs shall operate between 17 and 33 volts. Indoor SpectrAlert Advance products shall operate between 32 and 120 degrees Fahrenheit from a regulated DC or full-wave rectified unfiltered power supply. Strobes and horn strobes shall have field-selectable candela settings including 15, 15/75, 30, 75, 95, 110, 115, 135, 150, 177, and 185.

### Strobe

The strobe shall be a System Sensor SpectrAlert Advance Model \_\_\_\_\_ listed to UL 1971 and shall be approved for fire protective service. The strobe shall be wired as a primary-signaling notification appliance and comply with the Americans with Disabilities Act requirements for visible signaling appliances, flashing at 1 Hz over the strobe's entire operating voltage range. The strobe light shall consist of a xenon flash tube and associated lens/reflector system.

### Horn Strobe Combination

The horn strobe shall be a System Sensor SpectrAlert Advance Model \_\_\_\_\_ listed to UL 1971 and UL 464 and shall be approved for fire protective service. The horn strobe shall be wired as a primary-signaling notification appliance and comply with the Americans with Disabilities Act requirements for visible signaling appliances, flashing at 1 Hz over the strobe's entire operating voltage range. The strobe light shall consist of a xenon flash tube and associated lens/reflector system. The horn shall have three audibility options and an option to switch between a temporal three-pattern and a non-temporal (continuous) pattern. These options are set by a multiple position switch. On four-wire products, the strobe shall be powered independently of the sounder. The horn on horn strobe models shall operate on a coded or non-coded power supply.

### Synchronization Module

The module shall be a System Sensor Sync-Circuit model MDL listed to UL 464 and shall be approved for fire protective service. The module shall synchronize SpectrAlert strobes at 1 Hz and horns at temporal three. Also, while operating the strobes, the module shall silence the horns on horn strobe models over a single pair of wires. The module shall mount to a 4½/16 × 4½/16 × 2½/8-inch back box. The module shall also control two Style Y (class B) circuits or one Style 7 (class A) circuit. The module shall synchronize multiple zones. Daisy chaining two or more synchronization modules together will synchronize all the zones they control. The module shall not operate on a coded power supply.

## Physical/Electrical Specifications

Standard Operating Temperature	32°F to 120°F (0°C to 49°C)
Humidity Range	10 to 93% non-condensing
Strobe Flash Rate	1 flash per second
Nominal Voltage	Regulated 12 DC/FWR or regulated 24 DC/FWR <sup>1</sup>
Operating Voltage Range <sup>2</sup>	8 to 17.5 V (12 V nominal) or 16 to 33 V (24 V nominal)
Input Terminal Wire Gauge	12 to 18 AWG
Ceiling-Mount Dimensions (including lens)	6.8" diameter × 2.5" high (173 mm diameter × 64 mm high)
Wall-Mount Dimensions (including lens)	5.6" L × 4.7" W × 2.5" D (142 mm L × 119 mm W × 64 mm D)
Horn Dimensions	5.6" L × 4.7" W × 1.3" D (142 mm L × 119 mm W × 33 mm D)
Wall-Mount Back Box Skirt Dimensions (BBS-2, BBSW-2)	5.9" L × 5.0" W × 2.2" D (151 mm L × 128 mm W × 56 mm D)
Ceiling-Mount Back Box Skirt Dimensions (BBSC-2, BBSCW-2)	7.1" diameter × 2.2" high (180 mm diameter × 57 mm high)
Wall-Mount Trim Ring Dimensions (sold as a 5 pack) (TR-HS, TRW-HS)	5.7" L × 4.8" W × 0.35" D (145 mm L × 122 mm W × 9 mm D)
Ceiling-Mount Trim Ring Dimensions (sold as a 5 pack) (TRC-HS, TRCW-HS)	6.9" diameter × 0.35" high (175 mm diameter × 9 mm high)

### Notes:

1. Full Wave Rectified (FWR) voltage is a non-regulated, time-varying power source that is used on some power supply and panel outputs.
2. P, S, PC, and SC products will operate at 12 V nominal only for 15 and 15/75 cd.

## UL Current Draw Data

UL Max. Strobe Current Draw (mA RMS)						
	Candela	8-17.5 Volts		16-33 Volts		
		DC	FWR	DC	FWR	
<b>Standard</b>	15	123	128	66	71	
<b>Candela Range</b>	15/75	142	148	77	81	
	30	NA	NA	94	96	
	75	NA	NA	158	153	
	95	NA	NA	181	176	
	110	NA	NA	202	195	
<b>High</b>	115	NA	NA	210	205	
	135	NA	NA	228	207	
	<b>Candela Range</b>	150	NA	NA	246	220
		177	NA	NA	281	251
		185	NA	NA	286	258

UL Max. Horn Current Draw (mA RMS)					
Sound Pattern	dB	8-17.5 Volts		16-33 Volts	
		DC	FWR	DC	FWR
Temporal	High	57	55	69	75
Temporal	Medium	41	49	58	69
Temporal	Low	38	44	44	48
Non-temporal	High	57	56	69	75
Non-temporal	Medium	47	50	60	69
Non-temporal	Low	41	44	50	50
Coded	High	57	55	69	75
Coded	Medium	44	51	56	69
Coded	Low	40	46	52	50

UL Max. Current Draw (mA RMS), 2-Wire Horn Strobe, Standard Candela Range (15-115 cd)									
DC Input	8-17.5 Volts			16-33 Volts					
	15	15/75	15	15/75	30	75	95	110	115
Temporal High	137	147	79	90	107	176	194	212	218
Temporal Medium	132	144	69	80	97	157	182	201	210
Temporal Low	132	143	66	77	93	154	179	198	207
Non-Temporal High	141	152	91	100	116	176	201	221	229
Non-Temporal Medium	133	145	75	85	102	163	187	207	216
Non-Temporal Low	131	144	68	79	96	156	182	201	210
<b>FWR Input</b>									
Temporal High	136	155	88	97	112	168	190	210	218
Temporal Medium	129	152	78	88	103	160	184	202	206
Temporal Low	129	151	76	86	101	160	184	194	201
Non-Temporal High	142	161	103	112	126	181	203	221	229
Non-Temporal Medium	134	155	85	95	110	166	189	208	216
Non-Temporal Low	132	154	80	90	105	161	184	202	211


UL Max. Current Draw (mA RMS), 2-Wire Horn Strobe, High Candela Range (135-185 cd)									
DC Input	16-33 Volts				FWR Input	16-33 Volts			
	135	150	177	185		135	150	177	185
Temporal High	245	259	290	297	Temporal High	215	231	258	265
Temporal Medium	235	253	288	297	Temporal Medium	209	224	250	258
Temporal Low	232	251	282	292	Temporal Low	207	221	248	256
Non-Temporal High	255	270	303	309	Non-Temporal High	233	248	275	281
Non-Temporal Medium	242	259	293	299	Non-Temporal Medium	219	232	262	267
Non-Temporal Low	238	254	291	295	Non-Temporal Low	214	229	256	262

## Horn Tones and Sound Output Data

Horn and Horn Strobe Output (dBA)											
Switch Position	Sound Pattern	dB	8-17.5 Volts		16-33 Volts		24-Volt Nominal				
			DC	FWR	DC	FWR	Reverberant		Anechoic		
			DC	FWR	DC	FWR	DC	FWR	DC	FWR	
1	Temporal	High	78	78	84	84	88	88	99	98	
2	Temporal	Medium	74	74	80	80	86	86	96	96	
3	Temporal	Low	71	73	76	76	83	80	94	89	
4	Non-Temporal	High	82	82	88	88	93	92	100	100	
5	Non-Temporal	Medium	78	78	85	85	90	90	98	98	
6	Non-Temporal	Low	75	75	81	81	88	84	96	92	
7†	Coded	High	82	82	88	88	93	92	101	101	
8†	Coded	Medium	78	78	85	85	90	90	97	98	
9†	Coded	Low	75	75	81	81	88	85	96	92	

†Settings 7, 8, and 9 are not available on 2-wire horn strobe.

## SpectrAlert Advance Dimensions



## SpectrAlert Advance Ordering Information

Model	Description
<b>Wall Horn Strobes</b>	
P2R*†	2-Wire Horn Strobe, Standard cd, Red
P2RI*	2-Wire Horn Strobe, High cd, Red
P2W*	2-Wire Horn Strobe, Standard cd, White
P2WH*	2-Wire Horn Strobe, High cd, White
P4R*	4-Wire Horn Strobe, Standard cd, Red
P4RH	4-Wire Horn Strobe, High cd, Red
P4W	4-Wire Horn Strobe, Standard cd, White
<b>Wall Strobes</b>	
SR*†	Strobe, Standard cd, Red
SRH*†	Strobe, High cd, Red
SW*	Strobe, Standard cd, White
SWH*	Strobe, High cd, White
<b>Ceiling Horn Strobes</b>	
PC2R*	2-Wire Horn Strobe, Standard cd, Red
PC2RI	2-Wire Horn Strobe, High cd, Red
PC2W*†	2-Wire Horn Strobe, Standard cd, White
PC2WH*	2-Wire Horn Strobe, High cd, White
PC4R	4-Wire Horn Strobe, Standard cd, Red
PC4RH	4-Wire Horn Strobe, High cd, Red
PC4W	4-Wire Horn Strobe, Standard cd, White

Model	Description
<b>Ceiling Strobes</b>	
SCR	Strobe, Standard cd, Red
SCRH	Strobe, High cd, Red
SCW*	Strobe, Standard cd, White
SCWH	Strobe, High cd, White
<b>Horns</b>	
HR	Horn, Red
HW	Horn, White
<b>Accessories</b>	
BBS-2	Back Box Skirt, Wall, Red
BBSW-2	Back Box Skirt, Wall, White
BBSC-2	Back Box Skirt, Ceiling, Red
BBSCW-2	Back Box Skirt, Ceiling, White
TR-HS	Trim Ring, Wall, Red
TRW-IIS	Trim Ring, Wall White
TRC-IIS	Trim Ring, Ceiling, Red
TRCW-HS	Trim Ring, Ceiling, White

### Notes:

\* Add "-P" to model number for plain housing (no "FIRE" marking on cover), e.g., P2R-P.

† Add "-SP" to model number for "FUEGO" marking on cover, e.g., P2R-SP.

‡ "Standard cd" refers to strobes that include 15, 15/75, 30, 75, 95, 110, and 115 candela settings. "High cd" refers to strobes that include 135, 150, 177, and 185 candela settings.



3825 Ohio Avenue • St. Charles, IL 60174  
Phone: 800-SENSOR2 • Fax: 630-377-6495

©2009 System Sensor  
Product specifications subject to change without notice. Visit [system.sensor.com](http://system.sensor.com) for current product information, including the latest version of this data sheet.  
A05-0395-007 - 4/09 - #1132



**GENERAL NOTES:**

- THESE DRAWINGS ARE DIAGRAMMATIC. REFER TO THE ARCHITECTURAL DRAWINGS FOR EXACT DIMENSIONS.
- INSTALLATION SHALL COMPLY WITH NEC, NFPA 72 AND ALL OTHER APPLICABLE CODES AS REQUIRED BY THE LOCAL AUTHORITY HAVING JURISDICTION.
- WIRING DEPICTED ON THESE PLANS IS SCHEMATIC - ACTUAL WIRE LOCATIONS MAY DIFFER FROM THESE PLANS. WIRING SHALL BE PERFORMED AS ACTUAL BUILDING CONSTRUCTION CONDITIONS ALLOW AND TO MINIMIZE PENETRATIONS THROUGH AREA SEPARATION WALLS AND FIRE WALLS. THE USE OF A RACEWAY IS PERMITTED AS LONG AS NO 110V OR HIGHER VOLTAGE CABLES ARE IN THE SAME RACEWAY.
- FIRE RATINGS SHALL BE MAINTAINED FOR ALL PENETRATIONS THROUGH FIRE-RATED CONSTRUCTION.
- POWER FOR ALL FIRE ALARM PANELS AND FIRE ALARM POWER SUPPLIES MUST BE PROVIDED BY A DEDICATED AC BRANCH CIRCUIT.
- POWER-LIMITED AND NONPOWER-LIMITED CIRCUIT WIRING MUST REMAIN SEPARATED IN CABINET. ALL NONPOWER-LIMITED CIRCUIT WIRING MUST REMAIN AT LEAST 0.25" AWAY FROM ANY NONPOWER-LIMITED CIRCUIT WIRING. FURTHERMORE, ALL POWER-LIMITED AND NONPOWER-LIMITED CIRCUIT WIRING MUST ENTER AND EXIT THE CABINET THROUGH DIFFERENT KNOCK OUTS AND/OR SEPARATE CONDUITS.
- WHEN UTILIZING CLASS "A" CIRCUITS, SEPARATE OUTGOING AND RETURN CONDUCTORS OF CLASS "A" CIRCUITS BY A MINIMUM OF 12" WHERE RUN VERTICALLY AND 48" WHERE RUN HORIZONTALLY.
- WHEN UTILIZING SHIELDED CABLE THE SHIELDS THROUGH AND INSULATE AT EACH JUNCTION BOX. INSULATE AND TAPE BACK AT END.
- ALL FIRE ALARM CABLING SHALL BE ACCEPTABLE TO THE FIRE ALARM EQUIPMENT MANUFACTURER FOR THE INTENDED PURPOSE.
- SMOKE DETECTORS SHALL NOT BE INSTALLED UNTIL AFTER CONSTRUCTION CLEAN-UP IS COMPLETED AND FINAL.
- LOCATE SMOKE DETECTORS A MINIMUM OF THREE (3) FEET FROM MECHANICAL DIFFUSERS. WALL-MOUNTED SMOKE DETECTORS SHALL BE LOCATED A MINIMUM OF 4" AND A MAXIMUM OF 12" FROM CEILING. CEILING-MOUNTED SMOKE DETECTORS SHALL BE MOUNTED ON CEILINGS AND NOT ON THE BOTTOMS OF BEAMS OR JOISTS.
- PROVIDE SYNCHRONIZATION OF ALL VISUAL NOTIFICATION APPLIANCE CIRCUITS. PROVIDE ALL REQUIRED SYNC MODULES. PROVIDE A MULTI-SYNC MODE SLAVE CONNECTION BETWEEN ALL SYNC MODULES.
- VERIFY ALL FIELD SELECTABLE AUDIBILITY SETTINGS OF NOTIFICATION APPLIANCES WITH FIRE ALARM CONTRACTOR.
- UPON COMPLETION OF THE FIRE ALARM SYSTEM INSTALLATION AND PROGRAMMING, THE INSTALLING CONTRACTOR SHALL PERFORM FINAL TESTING OF THE ENTIRE SYSTEM PER ALL APPLICABLE CODES, AND SHALL COORDINATE AND PERFORM A FINAL FIRE ALARM SYSTEM INSPECTION.
- PROVIDE OFF-SITE MONITORING AS REQUIRED BY THE INTERNATIONAL FIRE CODE, SECTION 907.15 AND THE LOCAL AUTHORITY HAVING JURISDICTION.
- INSTALLING CONTRACTOR SHALL, PHYSICALLY, LABEL ALL INITIATING DEVICES AND NOTIFICATION APPLIANCE CIRCUIT END OF LINE (WHEN WIRING CLASS "B"). THESE LABELS SHALL BE IN PLACE PRIOR TO START-UP AND TESTING.
- THE FIRE ALARM SYSTEM BEING INSTALLED SHALL BE INTERCONNECTED TO THE EXISTING FIRE ALARM CONTROL PANEL IN ACCORDANCE WITH APPLICABLE STANDARDS.

FIRE ALARM SYMBOL LEGEND		
NOTE: ALL SYMBOLS NOT SHOWN ARE USED ON THIS PROJECT		
SYMBOL	DESCRIPTION	MOUNTING
[FCP]	FIRE ALARM CONTROL PANEL	WALL-TOP @ 66"
[FPS]	FIRE ALARM POWER SUPPLY	FIELD VERIFY
[FSA]	FIRE SYSTEM ANNUNCIATOR	WALL-TOP @ 66"
[FSD]	FIRE/SMOKE DAMPER	BY OTHERS
[SD]	SMOKE DETECTOR	CEILING
[DSM]	DUCT SMOKE DETECTOR	BY OTHERS
[HD]	HEAT DETECTOR	CEILING
[AM]	ADDRESSABLE CONTROL MODULE	FIELD VERIFY
[AMM]	ADDRESSABLE MONITOR MODULE	FIELD VERIFY
[MPS]	MANUAL PULL STATION	WALL @ 48"
[CR]	CONTROL RELAY (MULTI-VOLTAGE)	FIELD VERIFY
[ARM]	ADDRESSABLE RELAY MODULE	FIELD VERIFY
[MOH]	MAGNETIC OODR HOLDER	FIELD VERIFY
[WFS]	WATER FLOW SWITCH	BY OTHERS
[VTS]	VALVE TAMPER SWITCH	BY OTHERS
[B]	BELL	BY OTHERS
[CS]	CEILING MOUNT STROBE	FIELD VERIFY
[CHS]	CEILING MOUNT HORN / STROBE	FIELD VERIFY
[CMS]	CEILING MOUNT SPEAKER / STROBE	FIELD VERIFY
[H]	HORN	WALL @ 10'-0"
[HS]	HORN / STROBE	WALL 80"-96"
[SS]	SPEAKER / STROBE	WALL 80"-96"
[S]	SPEAKER	WALL @ 90"
[SBS]	STROBE	WALL 80"-96"


ABBREVIATION	DESCRIPTION
E	EXISTING
W	WITH GUARD
P	PENDENT MOUNT
R	RESIDENTIAL (110V)
S	SOUNDER BASE
HP	HEATER PROOF
EOL	END OF LINE RESISTOR
EOLR	END OF LINE RELAY
AWG	AMERICAN WIRE GAUGE
TWP	TWISTED PAIR
TWSP	TWISTED SHIELDED PAIR
FPLP	FIRE POWER LIMITED PLENUM
FPLR	FIRE POWER LIMITED RISER

**JOB NOTES:**

- THIS JOB IS A TENANT IMPROVEMENT MODIFYING ONLY THE ARIES SHOWN. PANEL, POWER SUPPLY, AND SYMBOLS ON THIS DRAWING MARKED WITH "E" ARE EXISTING. FIRE PANELS VIGNOLA FLOW SWITCH, AND EQUIPMENT LOCATED DIRECTLY BELOW THE OF THIS TENANT SPACE.

**SHEET NOTES:**

- EXISTING DEVICES TO BE REMOVED AND/OR RELOCATED TO REFLECT THE LOCATION SPECIFIED ON THIS PLAN. FIELD VERIFY EXACT MOUNTING, CIRCUITING, AND PROGRAMMING CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT EXACT QUANTITY AND LOCATION(S).
- ADDRESSABLE RELAY MODULE(S) PROVIDED FOR FAN SHUT DOWN. TIE TO INDICATED UNIT FAN CONTROLLER. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING, AND PROGRAMMING REQUIREMENTS. FIELD VERIFY POWER SOURCE. USE MULTI-VOLTAGE CONTROL RELAY(S) IF REQUIRED. FIELD VERIFY EXACT QUANTITY AND LOCATION(S) WITH MECHANICAL DIVISION.
- ADDRESSABLE RELAY MODULE(S) AND MULTI-VOLTAGE CONTROL RELAY(S) PROVIDED FOR DOOR HOLDER CONTROL. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY POWER SOURCE (24 VDC OR 120 VAC). USE MULTI-VOLTAGE CONTROL RELAY(S) IF REQUIRED. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).



Facility Information		Enter Standby and Alarm Times		Battery Configuration Factor
Location:	VIGNOLA CINQUE TERRE	Standby (hours):	24	10%
Account #:	UNICAD JOB #12049	Alarm Duration (minutes):	5	
Model:	Vista-128F BP		12.5	
Engineer:	C. HAWK			
Date:	2/13/2012			

SELECTED PANEL MAXIMUM OUTPUT RATINGS							
Panel Part	Standby Loop (mA)	Alarm Auxiliary Power (mA)	Panel Alarm (mA)	Panel Alarm (mA)	Bill #1 Output (mA)	Bill #2 Output (mA)	Maximum Panel Alarm Standby Output
Vista-128F BP	128	1000	1700	300	470	1700	1700
	28.0	120	200		0	0	141
	101.2	878.3	1489.3		1700.0	1700.0	653.1
							2073.1
							0.0

FPS Battery Calculation		NAC Circuit Voltage Drop Calculation	
Project Name:	VIGNOLA CINQUE TERRE	Project Name:	VIGNOLA CINQUE TERRE
Circuit Number:	NAC-1	Circuit Number:	NAC-1
Nominal System Voltage:	20.4 volts	Wire:	18 AWG
Minimum Device Voltage:	18 volts	Resistance Per 1000:	6.14
Distance from source to 1st device:	250'	Wire Gauge for balance of circuit:	14
Wire Gauge for balance of circuit:	14		8.14
Max Output Current:	3.0 amps		
Total Circuit Current:	1.627 amps		

Circuit is within limits				
Device	Current	Distance	Voltage at Device	Drop from source
Device 1 EXISTING DRAW	0.850	17.80	2.50	12%
Device 2	0.078	28	17.77	2.83
Device 3	0.178	22	17.87	2.73
Device 4	0.107	44	17.53	2.87
Device 5	0.107	31	17.45	2.95
Device 6	0.096	7	17.44	2.98
Device 7	0.179	45	17.37	3.03
Device 8	0.080	45	17.35	3.05
Totals	1.627	472		

**MAINE STATE SECURITY ALARMS**

Phone: (207) 247-4371  
Toll Free: (800) 273-4371

Small Enough To Care - Large Enough To Serve  
Family owned and operated

**VIGNOLA CINQUE TERRE T.I.**  
**36 WARF STREET**  
**PORTLAND, ME 04101**  
**FIRE ALARM DRAWING**

**UNICAD** Inc.

DRAWN: CWH UNICAD JOB #12049  
CHECKED: WAYNE B. HAWK NICTET N 90496  
DATE: 2/13/2012  
REVISION: 0  
SCALE: 1/8"=1'-0"

**FA-1**