



Restaurant Renovation
Vignola Cinque Terre
 10 Dana St. Portland Maine 04101 36 Warf St. Portland Maine 04101

LIFE SAFETY PLAN

BUILDING ENVELOPE
CONSULTANTS

191 STANFORD ST.
SOUTH PORTLAND
MAINE, 04106
TEL. 207-400-0086

DRAWN BY: DPD
 CHECKED BY: SRW
 ISSUE DATE: 12-28-2011
 PORTLAND PERMIT SET
 DATE: 12-28-2011

REVISIONS	
1	-

1 EXISTING MEZZANINE LEVEL WITH NEW LIFE SAFETY SHOWN

SCALE: 3/16"=1'-0"

LIFE SAFETY LEGEND	
	FIRE ALARM PULL AT EACH EXIT
	EMERGENCY ILLUMINATION
	SMOKE DETECTOR
	FIRE ALARM HORN STROBE
	ILLUMINATED EXIT SIGN
	FIRE EXTINGUISHER
	FIRE REMOTE ALARM PANELS

NOTES:
 1. DESIGN AND INSTALLATION OF FIRE ALARM PANEL, AND OTHER ELEMENTS BY OTHERS. THIS DRAWING INTENDED TO SHOW BASIC LAYOUT OF LIFE SAFETY SYSTEMS FOR APPROVAL BY A.H.J. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO COORDINATE DESIGN AND INSTALLATION WITH SUBCONTRACTORS AND OWNER. CONTRACTOR TO INSTALL A COMPLETE APPROVED AND WORKING SYSTEM BASED ON APPROVED DESIGN BY A.H.J REGARDLESS THE INFORMATION IN THIS DRAWING - THIS DRAWING FOR DESIGN INTENT ONLY.
 2. REUSE EXISTING ALARM FIXTURES AS POSSIBLE, PROVIDE TWO NEW REMOTE ANNUNCIATOR PANELS AT EACH RESTAURANT ENTRANCE TIED INTO THE MAIN PANEL.
 3. UPDATE KITCHEN HOOD SUPPRESSION SYSTEM AS NEEDED
 4. TIE EXISTING FIRE PROTECTION IN BASEMENT INTO NEW SYSTEM.

2 NOTES

A3
DRAWING NUMBER
 SCALE: 3/16"=1'-0"
 PROJECT NUMBER: 050-11

SCALE: 3/16"=1'-0"