

Grease Gutters provided? N/A

Hood Clearance reduction to Combustibles design /specs:

18" on top of Hood

Duct Clearance reduction to Combustibles design /specs:

Duct wrap with 3m grease duct wrap 615'

Vibration Isolation System:

N/A

Air Velocity within the duct system Sp. 2.000

Grease accumulation prevention system:

N/A

Cleanouts in 90° elbow first floor and on second floor

Grease Duct enclosure 3m grease duct wrap

Exhaust Termination Roof X Wall _____

Fire Suppression System other (fire safe)

Exhaust fan mounting and clearance from the roof / wall or Combustibles:

20" off roof 55" to top of fan and 10' away combustibles

Exhaust fan distance from property lines 10'

Exhaust fan distance from other vents or openings 10'

Exhaust fan distance from adjacent buildings 10'

Exhaust fan height above adjoining grade 20'

Hood Specs

Style of Hood Canopy

Type of Filter grease baffles

Height of filter above nearest cooking surface 36"

Capacity of hood CFM 2992 cfm

Make up Air system description and capacity

make up air to sit upon roof 10' away from exhaust fan
Then duct into building with 24ga galv ductwork
Bans in 2094 AT LSP.