

To: Portland Fire Department

From: Eastern Fire Services

Re: Forq Food Labs Fire Alarm Scope of Work

Date: 5/17/16

This project consists of an existing building being renovated to accommodate a new commercial kitchen facility and culinary preparation. This industrial occupancy will not be equipped with an automatic fire sprinkler system.

A new manual fire alarm system shall be installed per NFPA 101, 72 and ADA requirements for the hearing impaired. Suppression systems for commercial cooking equipment shall be monitored by the fire alarm system and gas fired equipment shall be shut down where applicable. Upon fire alarm Portland Fire Department shall be notified via central station as required.

Please do not hesitate to contact with any questions.

Sincerely,

Colby Malcolm

malcolmcr@efp-efs.com