Install Date: 2016
Fork Food Lab
272 Lancaster Street
Portland, ME 04101

All State Fire Equipme
20C Del Carmine Stree
Wakefield, MA 01880
Steve Keefe
781-224-1001
skeefe@lfpfire.com
4612

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/13/16

Ansul R102 UL 300

Flow Summary:

Coverage	Overall Dimensions	Nozzle	Flows	Nozzle Location
Hood: Single Bank	156 x 54 in.	1N x2	2	2-4 in. from filter face, center of height dimension, aimed down filter length.
Duct: Square	16 x 14 in.	2W	2	2-8 in. into center of duct opening, aimed up
Range: 4 burners	24 x 30 in.	245	2	40-50 in., center of cooking surface, or 11 3/8 in. max to centerline of any gr ... See Note 3
Range: 6 burners	36 x 30 in.	1N x3	3	30-40 in., 0-10 in. from each burner centerline, aimed at midpoint
Range: 2 burners	18 x 30 in.	245	2	40-50 in., center of cooking surface, or 11 3/8 in. max to centerline of any gr ... See Note 4
Total Flow Points			11	