

Record of Completion

Presented To

Parris Terraces

60 Parris Street
Portland ME 04101
USA

This site has been inspected and tested in compliance with applicable standards.

Completed
Friday, May 31, 2019

Test Session: Occupancy Testing 05/31/19

ACCEPTED BY

Parris Terraces
60 Parris Street
Portland ME 04101
USA

TESTED BY

Michael Todd
Norris Inc
2257 Broadway
South Portland ME 4106
USA

Inspection Location and Organizations

Building Information

PROPERTY	Parris Terraces	CONTACT
ADDRESS	60 Parris Street	PHONE
CITY/STATE/ZIP	Portland, ME 04101	MOBILE
COUNTRY	USA	EMAIL

Installer Information

NAME	Bruce Milliken Electrical
ADDRESS	59 Middle Street. Portland, Maine 04101
PHONE	(207) 797-9192
EMAIL	

Service Company Information

NAME	Norris Inc
ADDRESS	2257 Broadway South Portland ME 04106
PHONE	(207) 883-3473
EMAIL	NICentralOperations@norrisinc.com

Testing Company Information

NAME	Norris Inc
ADDRESS	2257 Broadway South Portland ME 04106
PHONE	(207) 883-3473
EMAIL	NICentralOperations@norrisinc.com
CONTRACT DATE	

Description of Service

This is a new system.
Permit #
NFPA72 Edition: 2013
Number of devices participating in Alarm Verification: 0

Initiating Device Summary

EQUIPMENT TYPE	TOTAL
Initiating Device	27
Fire Control Panel	4
Alarm Notification Appliance	36
Supervising Station Transmitting Equipment	2
Emergency Control Equipment	3

Notification Device Summary

EQUIPMENT TYPE	TOTAL
Initiating Device	27
Fire Control Panel	4
Alarm Notification Appliance	36
Supervising Station Transmitting Equipment	2
Emergency Control Equipment	3

Device Summary

Norris Inc

EQUIPMENT TYPE	TOTAL
Initiating Device	27
Fire Control Panel	4
Alarm Notification Appliance	36
Supervising Station Transmitting Equipment	2
Emergency Control Equipment	3

System Control Functions

Function	Count
Fan Control	0
Smoke Damper	0
HVAC Shutdown	0
Elevator Recall	2
Elevator Power Shutdown	0
Elevator Short Trip	0
Door Holder Release	0
Shutter Release	0
Door Unlock	0
Other	1

Certification Information

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Friday, May 31, 2019

INSTALLED BY

6/3/2019

Bruce Milliken Electrical
Installer

TESTED BY



6/3/2019

Michael Todd
Technician

ACCEPTED BY

6/3/2019

Building Representative

ACCEPTED BY

6/3/2019

Portland Fire Department
AHJ

Testing Details

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Main Entry NFW-100X	Manual	6/3/2019 2:25 PM
Fire Panel Batteries		Inside FACP	Manual	6/3/2019 2:25 PM
FCPS		1st Floor Sprinkler Closet	Manual	6/3/2019 2:25 PM
FCPS Batteries		Inside FCPS (Sprinkler Closet)	Manual	6/3/2019 2:25 PM

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	D01	1st Floor Above FACP	Manual	6/3/2019 2:24 PM
Smoke Detector - General	D02	1st Floor O/S 101	Manual	6/3/2019 2:24 PM
Smoke Detector - General	D03	1st Floor Elevator Lobby	Manual	6/3/2019 2:25 PM
Smoke Detector - General	D04	1st Floor Sprinkler Riser Closet	Manual	6/3/2019 2:25 PM
Smoke Detector - General	D07	2nd Floor Elevator Lobby	Manual	6/3/2019 2:25 PM
Smoke Detector - General	D08	2nd Floor O/S 202	Manual	6/3/2019 2:25 PM
Smoke Detector - General	D10	3rd Floor Elevator Lobby	Manual	6/3/2019 2:25 PM
Smoke Detector - General	D11	3rd Floor O/S 302	Manual	6/3/2019 2:25 PM
Smoke Detector - General	D13	4th Floor Elevator Lobby	Manual	6/3/2019 2:25 PM
Smoke Detector - General	D14	Elevator Top of Shaft	Manual	6/3/2019 2:25 PM
Smoke Detector - General	D16	4th Floor O/S 402	Manual	6/3/2019 2:25 PM
Manual Pull Station	M03	1st Floor Vestibule	Manual	6/3/2019 2:25 PM
Manual Pull Station	M04	1st Floor Trash Room	Manual	6/3/2019 2:25 PM
Carbon Monoxide detector	M05	1st Floor Mechanical Room	Manual	6/3/2019 2:25 PM
Manual Pull Station	M06	1st Floor Rear Exit	Manual	6/3/2019 2:25 PM
Supervisory - High/Low Air Pressure Switch	M07	Sprinkler Pressure Switch	Manual	6/3/2019 2:25 PM
Valve Tamper Switch	M08	1st Floor Sprinkler Tampers	Manual	6/3/2019 2:25 PM
Mechanical, Electrosonic, or Pressure Waterflow Device	M09	Sprinkler Waterflow Switch	Manual	6/3/2019 2:25 PM
Manual Pull Station	M10	1st Floor Stair 1 Exit	Manual	6/3/2019 2:25 PM
Valve Tamper Switch	M11	1st Floor Stair Sprinkler Tamper	Manual	6/3/2019 2:25 PM
Manual Pull Station	M12	1st Floor Stair 2 Exit	Manual	6/3/2019 2:25 PM
Manual Pull Station	M13	2nd Floor Stair 2 Exit	Manual	6/3/2019 2:25 PM
Manual Pull Station	M14	2nd Floor Stair 1	Manual	6/3/2019 2:25 PM
Manual Pull Station	M15	3rd Floor Stair 2	Manual	6/3/2019 2:25 PM
Manual Pull Station	M16	3rd Floor Stair 1	Manual	6/3/2019 2:25 PM
Manual Pull Station	M17	4th Floor Stair 2	Manual	6/3/2019 2:25 PM
Manual Pull Station	M22	4th Floor Stair 1	Manual	6/3/2019 2:25 PM

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible		Exterior Strobe	Manual	6/3/2019 2:25 PM
Audible And Visible		1st Floor Office	Manual	6/3/2019 2:25 PM

Norris Inc

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		1st Floor Vestibule	Manual	6/3/2019 2:25 PM
Audible And Visible		1st Floor Mechanical Room	Manual	6/3/2019 2:25 PM
Audible And Visible		1st Floor Corridor O/S Guest	Manual	6/3/2019 2:25 PM
Audible		Guest 101	Manual	6/3/2019 2:26 PM
Audible		Unit 102	Manual	6/3/2019 2:26 PM
Audible And Visible		1st Floor Corridor O/S 103	Manual	6/3/2019 2:26 PM
Audible		Unit 103	Manual	6/3/2019 2:26 PM
Audible And Visible		2nd Floor Corridor O/S 202	Manual	6/3/2019 2:26 PM
Audible		Unit 202	Manual	6/3/2019 2:26 PM
Audible		Unit 201	Manual	6/3/2019 2:26 PM
Audible		Unit 207	Manual	6/3/2019 2:26 PM
Audible		Unit 206	Manual	6/3/2019 2:26 PM
Audible		Unit 205	Manual	6/3/2019 2:26 PM
Audible		Unit 204	Manual	6/3/2019 2:26 PM
Audible		Unit 203	Manual	6/3/2019 2:26 PM
Audible And Visible		2nd Floor Corridor O/S 203	Manual	6/3/2019 2:26 PM
Audible And Visible		3rd Floor Corridor O/S 302	Manual	6/3/2019 2:26 PM
Audible		Unit 302	Manual	6/3/2019 2:26 PM
Audible		Unit 301	Manual	6/3/2019 2:26 PM
Audible		Unit 307	Manual	6/3/2019 2:26 PM
Audible		Unit 306	Manual	6/3/2019 2:26 PM
Audible		Unit 305	Manual	6/3/2019 2:26 PM
Audible		Unit 304	Manual	6/3/2019 2:26 PM
Audible		Unit 303	Manual	6/3/2019 2:26 PM
Audible And Visible		3rd Floor Corridor O/S 303	Manual	6/3/2019 2:26 PM
Audible And Visible		4th Floor Corridor O/S 402	Manual	6/3/2019 2:26 PM
Audible		Unit 402	Manual	6/3/2019 2:26 PM
Audible		Unit 401	Manual	6/3/2019 2:26 PM
Audible		Unit 407	Manual	6/3/2019 2:26 PM
Audible		Unit 406	Manual	6/3/2019 2:27 PM
Audible		Unit 405	Manual	6/3/2019 2:27 PM
Audible		Unit 404	Manual	6/3/2019 2:27 PM
Audible		Unit 403	Manual	6/3/2019 2:27 PM
Audible And Visible		4th Floor Corridor O/S 403	Manual	6/3/2019 2:27 PM

Supervising Station Transmitting Equipment

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Digital Alarm Communicator Transmitter		On Board DACT	Manual	6/3/2019 2:25 PM
Radio Alarm Transmitter		Portland City AES box (Sprinkler Closet)	Manual	6/3/2019 2:25 PM

Emergency Control Equipment

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Elevator Recall	M18	Elevator Primary Recall	Manual	6/3/2019 2:24 PM
Elevator Recall	M19	Elevator Alternate Recall	Manual	6/3/2019 2:24 PM
Elevator Flashing Hat	M20	Elevator Fireman's Hat	Manual	6/3/2019 2:24 PM

Device/Equipment Details

Fire Control Panel

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
FCPS					
	1st Floor Sprinkler Closet	Notifier	FCPS 24S8		5/6/2019
FCPS Batteries					
	Inside FCPS (Sprinkler Closet)		12v12ah		5/6/2019
Fire Alarm Panel					
	Main Entry NFW-100X	Notifier	NFW-100X		5/6/2019
Fire Panel Batteries					
	Inside FACP		12v12ah		5/6/2019

Initiating Device

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Carbon Monoxide detector					
M05	1st Floor Mechanical Room	System Sensor	CO-1224		5/6/2019
Manual Pull Station					
M17	4th Floor Stair 2	Notifier	NOT-BG-12LX		5/6/2019
M04	1st Floor Trash Room	Notifier	NOT-BG-12LX		5/6/2019
M13	2nd Floor Stair 2 Exit	Notifier	NOT-BG-12LX		5/6/2019
M06	1st Floor Rear Exit	Notifier	NOT-BG-12LX		5/6/2019
M15	3rd Floor Stair 2	Notifier	NOT-BG-12LX		5/6/2019
M10	1st Floor Stair 1 Exit	Notifier	NOT-BG-12LX		5/6/2019
M22	4th Floor Stair 1	Notifier	NOT-BG-12LX		5/6/2019
M14	2nd Floor Stair 1	Notifier	NOT-BG-12LX		5/6/2019
M03	1st Floor Vestibule	Notifier	NOT-BG-12LX		5/6/2019
M16	3rd Floor Stair 1	Notifier	NOT-BG-12LX		5/6/2019
M12	1st Floor Stair 2 Exit	Notifier	NOT-BG-12LX		5/6/2019
Mechanical, Electrosonic, or Pressure Waterflow Device					
M09	Sprinkler Waterflow Switch				5/6/2019
Smoke Detector - General					
D16	4th Floor O/S 402	Notifier	NP-100		5/6/2019
D13	4th Floor Elevator Lobby	Notifier	NP-100		5/6/2019
D01	1st Floor Above FACP	Notifier	NP-100		5/6/2019
D02	1st Floor O/S 101	Notifier	NP-100		5/6/2019
D11	3rd Floor O/S 302	Notifier	NP-100		5/6/2019
D07	2nd Floor Elevator Lobby	Notifier	NP-100		5/6/2019
D14	Elevator Top of Shaft	Notifier	NP-100		5/6/2019
D08	2nd Floor O/S 202	Notifier	NP-100		5/6/2019
D03	1st Floor Elevator Lobby	Notifier	NP-100		5/6/2019
D10	3rd Floor Elevator Lobby	Notifier	NP-100		5/6/2019
D04	1st Floor Sprinkler Riser Closet	Notifier	NP-100		5/6/2019
Supervisory - High/Low Air Pressure Switch					
M07	Sprinkler Pressure Switch				5/6/2019
Valve Tamper Switch					
M11	1st Floor Stair Sprinkler Tamper				5/6/2019
M08	1st Floor Sprinkler Tamper				5/6/2019

Alarm Notification Appliance

Norris Inc

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Audible					
	Unit 201	System Sensor	MHW		5/6/2019
	Unit 402	System Sensor	MHW		5/6/2019
	Unit 206	System Sensor	MHW		5/6/2019
	Unit 306	System Sensor	MHW		5/6/2019
	Unit 204	System Sensor	MHW		5/6/2019
	Unit 301	System Sensor	MHW		5/6/2019
	Unit 304	System Sensor	MHW		5/6/2019
	Unit 103	System Sensor	MHW		5/6/2019
	Unit 202	System Sensor	MHW		5/6/2019
	Guest 101	System Sensor	MHW		5/6/2019
	Unit 207	System Sensor	MHW		5/6/2019
	Unit 203	System Sensor	MHW		5/6/2019
	Unit 205	System Sensor	MHW		5/6/2019
	Unit 307	System Sensor	MHW		5/6/2019
	Unit 405	System Sensor	MHW		5/6/2019
	Unit 303	System Sensor	MHW		5/6/2019
	Unit 406	System Sensor	MHW		5/6/2019
	Unit 302	System Sensor	MHW		5/6/2019
	Unit 404	System Sensor	MHW		5/6/2019
	Unit 403	System Sensor	MHW		5/6/2019
	Unit 305	System Sensor	MHW		5/6/2019
	Unit 407	System Sensor	MHW		5/6/2019
	Unit 102	System Sensor	MHW		5/6/2019
	Unit 401	System Sensor	MHW		5/31/2019

Audible And Visible					
	2nd Floor Corridor O/S 202	System Sensor	P2RL		5/6/2019
	3rd Floor Corridor O/S 303	System Sensor	P2RL		5/6/2019
	2nd Floor Corridor O/S 203	System Sensor	P2RL		5/6/2019
	3rd Floor Corridor O/S 302	System Sensor	P2RL		5/6/2019
	4th Floor Corridor O/S 403	System Sensor	P2RL		5/6/2019
	1st Floor Mechanical Room	System Sensor	P2RL		5/6/2019
	1st Floor Office	System Sensor			5/6/2019
	1st Floor Vestibule	System Sensor	P2RL		5/6/2019
	1st Floor Corridor O/S 103	System Sensor	P2RL		5/6/2019
	4th Floor Corridor O/S 402	System Sensor	P2RL		5/6/2019
	1st Floor Corridor O/S Guest	System Sensor	P2RL		5/6/2019

Visible					
	Exterior Strobe	System Sensor			5/6/2019

Supervising Station Transmitting Equipment

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Digital Alarm Communicator Transmitter					
	On Board DACT	Notifier	NFW-100X built in DACT		5/6/2019

Radio Alarm Transmitter					
	Portland City AES box (Sprinkler Closet)	AES			5/31/2019

Emergency Control Equipment

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Elevator Flashing Hat					

Norris Inc

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
M20	Elevator Fireman's Hat	Notifier	NC-100R		5/6/2019
Elevator Recall					
M18	Elevator Primary Recall	Notifier	NC-100R		5/6/2019
M19	Elevator Alternate Recall	Notifier	NC-100R		5/6/2019

Supplementary Information

Monitoring Information

TYPE	Radio Alarm Transmitter	DESCRIPTION	Portland City AES box (Sprinkler Closet)
ORGANIZATION NAME	Portland Fire	ACCOUNT NUMBER	
ORGANIZATION ADDR.		PHONE LINE 1	
ORGANIZATION PHONE		PHONE LINE 2	
ORGANIZATION EMAIL		ENTITY TO RETRANSMIT ALARMS TO	

TYPE	Digital Alarm Communicator Transmitter	DESCRIPTION	On Board DACT
ORGANIZATION NAME	Cunningham Security	ACCOUNT NUMBER	6300-8680
ORGANIZATION ADDR.		PHONE LINE 1	
ORGANIZATION PHONE		PHONE LINE 2	
ORGANIZATION EMAIL		ENTITY TO RETRANSMIT ALARMS TO	Portland Fire