

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK

CITY OF PORTLAND

BUILDING INSPECTION

PERMIT

Please Read Application And Notes, If Any, Attached

Permit Number: 0804

PERMIT ISSUED

MAY 13 2008

CITY OF PORTLAND

This is to certify that ISLAMIC SOCIETY OF PORTLAND MAINE / Lameur Home Impr

has permission to Add wall

AT 73 PORTLAND ST 033 A018001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and when permission procured before this building or part thereof is altered or closed-in. **24 HOUR NOTICE IS REQUIRED.**

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. Greg Clark

Health Dept. _____

Appeal Board _____

Other _____

Department Name _____

Jeannie Bowke 5/9/08

Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 08-0423	Issue Date:	CBL: 033 A018001
-----------------------	-------------	---------------------


Location of Construction: 73 PORTLAND ST	Owner Name: ISLAMIC SOCIETY OF PORTLA	Owner Address: PO BOX 10294	Phone:
Business Name:	Contractor Name: Lameur Home Improvement	Contractor Address: 592 Washington Ave Portland	Phone 2076715061
Lessee/Buyer's Name	Phone:	Permit Type: <i>Amendment</i> Change of Use - Commercial	Zone: <i>B-2b</i>

Past Use: Private Club - Connected w/ permit#070265	Proposed Use: Private Club - Connected w/ permit#070265 - Add wall (<i>interior</i>)	Permit Fee: \$105.00	Cost of Work: \$710.00	CEO District: 1
Proposed Project Description: Add wall (<i>interior</i>)		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: <i>B</i> Type: <i>SB</i> <i>DEC-2003</i>	

Signature: <i>Creey Cross</i>		Signature: <i>AMB 5/9/08</i>	
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)			
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied			
Signature:		Date:	

Permit Taken By: ldobson	Date Applied For: 04/28/2008	Zoning Approval	
-----------------------------	---------------------------------	------------------------	--

<ol style="list-style-type: none"> This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. Building permits do not include plumbing, septic or electrical work. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.. 	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date: <i>9/4/29/08</i>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date:
---	--	---	--



CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE

5/24/08

Fire walls must extend to bottom of deck ^{floor}

By closet in retail fire walls on 5/8 - 45 seen by cam JSM - By closet space

Assembly space back wall not 5/8 - All walls must be conformed. Benw & SMH. No close allowed SMH

12/1/08 See new drawings for wall submitted JmB
will Remove drop ceiling - strap to 5/8 sheetrock
on ceiling joists. wall to be built to ceiling w/ 5/8 both
sides. Sprinklers installed JmB

1/14/08 close - Need -
2 layers hallway Exit ceiling
5/8 - Single layer in retail space
If the door requires to retail + closer
Retail closer on door - from prayer -
1 additional layer 5/8 on closer in
entrance to back -
re sheet rock back wall from prayer space

prayer space CO would be limited to

- Exit from prayer space near door enclosure
permit Amusement around SMH

02/19/09 work completed
SMH