#### 45-47 HANOVER STREET



# CITY OF PORTLAND, MAINE DEPARTMENT OF BUILDING INSPECTION

# COMPLAINT

INSPECTION COPY
COMPLAINT NO. 82-41 Date Receiv

Date Received May 26, 1982

	49 Hanover Street	Use of Building_	dwelling
Location		2	Telephonenone_listed
Owner's name	e and address Mr. Stetson - same		Telephone
Tenant's name	e and address	Alder St.	
Complainant's	s name and address John Winch Jr50	hout the conditi	ons of the house
:	at 49 Hanover, which is in back of livestock of some kind being raised last house on right side of street		
NOTES:	> vorend course brasans	- m. Ward	says it okin
<u>5 27 82</u>	E-2 gove VI		
· ·			
A-1			
****			
<del>, ,</del>			
		<del></del>	
16-40-16-16-16-16-16-16-16-16-16-16-16-16-16-			
the second second second	The state of the s		



### CITY OF POFTLAND, MAINE DEPARTMENT OF BUILDING INSPECTION

## COMPLAINT

INSPECTION COPY

OMPLAINT NO. 80/98	Date Received Dec. 17, 1950
--------------------	-----------------------------

Location 37 (or 67) Hanover St.  Last bldg. on right side  Owner's name and address Mr. Stetson		'
		Telephone
Complainant's name and address	. Telephone	
Complainant's name and address John Winch, Jr.  Description:	Telephone 773-6998	
-		
Addition on rear (used for NOTES:	chicken coop)	is falling down

PS Form 3800, Feb, 1982 RECEIFT FOR LERTIFIEL STU 4.52 2EU AY Hanqver ------

DF PORTLAND

LANNING & URBAH DEVELOPMENT INSPECTION SERVICES DIVISION

April 9, 1987

Edward Stetson 49 Hanover Street Portland, ME 04161

Re: 49 Hanover St.

Dear Mr. Stetson:

We recently received a complaint and an inspection was made by Code Enforcement of the property owned by you at 49 Hanover Street Portland, Maine. As a result of the inspection, you are hereby ordered to correct the following substandard housing conditions:

- 1. FRONT CHIMNEY ABOVE ROOF missing bricks and mortar. 6-108
- 2. OVERALL EXTERIOR walls missing siding. 6-108
- 3. RIGHT ROOF broken drain. 6-108 4. RIGHT ROOF rotted eave. 6-108
- 5. LEFT EXTERIOR foundation missing mortar. 6-108
- 6. RIGHT PORCH steps broken and rotted. 6-108

The showe mentioned conditions are in violation of Article V of the Municipal Code of the Caty of Portland, Maine, and must be corrected on or before June 9, 1987

Failure to comply with this c. - ... may result in a complaint being filed for prosecution in District Court.

> Sincerely yours,
> Joseph E. Gray, Jr., Director of Planning & Urban Development

> > Chief of The pection Services

Code Enforcement Officer -

jmc