

951158

PERMIT ISSUED

NOV - 7 1995

CITY OF PORTLAND

FILL IN AND SIGN WITH INK



APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, 11/6/95

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 88 Preble St Use of Building homeless shelter Stories New Building Existing " Name and address of owner of appliance Salvation Army Installer's name and address Mechanical Services Inc 774-1531 Telephone 400 Presumpscot St- Ptld ME 04103

General Description of Work

To install replacement steam boiler

IF HEATER OR POWER BOILER

Location of appliance cellar Any burnable material in floor surface or beneath? no If so, how protected? Kind of fuel? natural gas Minimum distance to burnable material, from top of appliance or casing top of furnace 5 ft From top of smoke pipe 2 ft From front of appliance 10 ft From sides or back of appliance 5/15 ft Size of chimney flue 18 inch Other connections to same flue no If gas fired, how vented? chimney Rated maximum demand per hour 660,000 btu Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Labelled by underwriters' laboratories? Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? Type of floor beneath burner Size of vent pipe:

33-D-01

Blank lines for additional information or notes.

- 1. 1/2" FILL PIPE
2. 1 1/4" VENT PIPE
3. Kind of heat
4. Burner rigidity & support
5. Name & Label
6. Remote control
7. High limit control
8. Main cutoff switch
9. Low water cutoff
10. High limit control
11. Piping support & protection
12. Valves in supply line
13. Capacity of tanks
14. Tank rigidity & support
15. Oil gauge
16. Instruction card
17. Oil leaks
18. Adequate ventilation
19. Smokepipe to combustor
20. Ventured devices - service