COPYRIGHT: Reuse or reproduction of the contents of this document is not permitted without written permission of Ripcord Engineering Inc.



1 DINING HALL HVAC PLAN
1/8" = 1'0"

GENERAL NOTES

1. DROP DOWN FROM BRANCH DUCTING TO ALL SUPPLY AIR DIFFUSERS IN THE SEATING AREA SO THAT THEY ARE LEVEL WITH THE LIGHTS, APPROXIMATELY 11 FEET ABOVE FINISHED FLOOR. COORDINATE WITH ARCHITECT.

KEY NOTES

1 CUT INTO EXISTING THRIFT STORE ROOF TO TIE IN NEW GRAVITY INLET HOOD. COORDINATE WITH ARCHITECT ND STRUCTURAL ENGINEER IN THE FIELD. LOCATION CAN BE ADJUSTED TO ACCOMMODATE EXISTING BUILDING STRUCTURE.

Ripcord Engineering
PO Box 4175
Portland, ME
04101
207 331 7900
sonia.barrantes@ripcordengineering.com

RIPCORD ENGINEERING

STATE OF MAINE
SONIA M. BARRANTES
No. 13557
10/25/16
LICENSED
PROFESSIONAL ENGINEER

PROJECT NO.
15031
PROJECT NAME
SALVATION ARMY ARC
PORTLAND, ME

REVISIONS
1 -
2 -
3 -
4 -
5 -

DRAWN BY
SMB
SHEET TITLE
DINING HALL HVAC PLAN

CONSTRUCTION DOCUMENTS

ISSUE DATE
10/25/16
SHEET SCALE
1/8" = 1'0"

M

M101