



Certificate of Occupancy

CITY OF PORTLAND, MAINE

Permitting and Inspections Department
Building Inspections Division



Location: 88 PREBLE ST

CBL: 033 D011001

Issued To: SALVATION ARMY THE

Issued Date: 02/28/2018

This is to certify that the building, premises, or part thereof, at the above location, built-altered-changed as to use under Building Permit No. 201602844 has had a final inspection, has been found to conform substantially to the requirements of the Building Code and the Land Use Code of the City of Portland, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

New Cafeteria

APPROVED OCCUPANCY ZONING

new dining room & kitchen on first floor
and new dwelling unit on second floor

APPROVED OCCUPANCY BUILDING

Residential Boarding House - existing occupant load
Residential Single Dwelling - 6 occupants
Dining Hall/Kitchen - 194
Total building occupant load = 547
NFPA 13 sprinkler system in existing building
Non sprinkled in new addition-separate fire area
Use Group R-2, R-3, A-2
Type 3B
MUBEC/IBC 2009

LIMITING CONDITIONS:

Approved: /S/ Chuck Fagone

Inspector

Inspection Division Director