



... Fire Protection by Computer Design

High Tech Fire Protection
84 Hackett Mills Rd
PO Box 156
Poland, ME, 04274
207-998-2551

Job Name : Schlotterbeck Block
Building : FP-02
Location : 117 Preble Street
System : 2
Contract :
Data File : 4th Floor Calc.WXF

HYDRAULIC CALCULATIONS
for

Project name: Schlotterbeck Block
Location: 117 Preble Street
Drawing no: FP-02
Date: 5-18-2016

Design

Remote area number: 2
Remote area location: 4th Floor
Occupancy classification: Light
Density: .1 - Gpm/SqFt
Area of application: 220 - SqFt
Coverage per sprinkler: 256 - SqFt
Type of sprinklers calculated: Residential Uprights
No. of sprinklers calculated: 4
In-rack demand: - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 212.619 - GPM @ 90.712 - Psi
Type of system: NFPA 13 Wet
Volume of dry or preaction system: - Gal

Water supply information

Date: 10-28-2014
Location: Riser
Source: Main Drain Tag

Name of contractor: High Tech Fire Protection
Address: 84 Hackett Mills Rd / PO Box 156 / Poland, ME, 04274
Phone number: 207-998-2551
Name of designer: Ed Pennell
Authority having jurisdiction: Portland Fire Department
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve (C)

High Tech Fire Protection
Schlotterbeck Block

Page 2
Date

City Water Supply:
C1 - Static Pressure : 112
C2 - Residual Pressure: 108
C2 - Residual Flow : 1342

Demand:
D1 - Elevation : 23.387
D2 - System Flow : 112.619
D2 - System Pressure : 90.712
Hose (Demand) : 100
D3 - System Demand : 212.619
Safety Margin : 21.156



Fittings Used Summary

High Tech Fire Protection
Schlotterbeck Block

Page 3
Date

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

High Tech Fire Protection
Schlotterbeck Block

Page 4
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	0.0	4.9	27.3	na	25.6	0.1	256	13.5
DP2	0.0	4.9	27.3	na	25.6	0.1	256	13.5
1B	54.0	K = K @ EQ01	27.91	na	25.6			
2B	54.0	K = K @ EQ02	29.45	na	26.01			
3B	55.0		35.71	na				
4B	55.0		37.97	na				
5B	55.0	K = K @ EQ02	38.64	na	29.79			
P*	0.0		51.3	na				
7B	54.0	K = K @ EQ01	41.5	na	31.21			
8B	54.0		45.05	na				
9B	55.0		45.05	na				
10B	55.0		45.36	na				
6B	55.0		46.18	na				
12B	55.0		46.73	na				
13B	10.0		79.09	na				
11	10.0		79.28	na				
TOR	3.0		82.71	na				
BOR	3.0		85.77	na				
UG0	3.0		89.29	na				
UG1	3.0		89.32	na				
UG2	3.0		89.4	na				
TEST	0.0		90.71	na	100.0			

The maximum velocity is 19.16 and it occurs in the pipe between nodes 2B and 3B

Final Calculations - Hazen-Williams

High Tech Fire Protection
Schlotterbeck Block

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	25.60 25.6	1.049 120.0 0.2057	1E	2.0 0.0 0.0	1.000 2.000 3.000	27.295 0.0 0.617			K Factor = 4.90 Vel = 9.50	
	0.0 25.60					27.912			K Factor = 4.85	
DP2 to EQ02	25.60 25.6	1.049 120.0 0.2055	1T	5.0 0.0 0.0	1.000 5.000 6.000	27.295 0.0 1.233			K Factor = 4.90 Vel = 9.50	
	0.0 25.60					28.528			K Factor = 4.79	
1B to 2B	25.60 25.6	1.049 120.0 0.2055		0.0 0.0 0.0	7.500 0.0 7.500	27.912 0.0 1.541			K Factor @ node EQ01 Vel = 9.50	
2B to 3B	26.01 51.61	1.049 120.0 0.7517	1E	2.0 0.0 0.0	6.900 2.000 8.900	29.453 -0.433 6.690			K Factor @ node EQ02 Vel = 19.16	
3B to 4B	0.0 51.61	1.049 120.0 0.7517	1E	2.0 0.0 0.0	1.000 2.000 3.000	35.710 0.0 2.255			Vel = 19.16	
4B to 5B	0.0 51.61	1.049 120.0 0.7522		0.0 0.0 0.0	0.900 0.0 0.900	37.965 0.0 0.677			Vel = 19.16	
5B to 6B	29.80 81.41	1.38 120.0 0.4593	1T	6.0 0.0 0.0	10.400 6.000 16.400	38.642 0.0 7.533			K Factor @ node EQ02 Vel = 17.46	
	0.0 81.41					46.175			K Factor = 11.98	
7B to 8B	31.21 31.21	1.049 120.0 0.2965		0.0 0.0 0.0	12.000 0.0 12.000	41.495 0.0 3.558			K Factor @ node EQ01 Vel = 11.59	
8B to 9B	0.0 31.21	1.38 120.0 0.0780	1E	3.0 0.0 0.0	2.500 3.000 5.500	45.053 -0.433 0.429			Vel = 6.69	
9B to 10B	0.0 31.21	1.38 120.0 0.0780	1E	3.0 0.0 0.0	1.000 3.000 4.000	45.049 0.0 0.312			Vel = 6.69	
10B to 12B	0.0 31.21	1.38 120.0 0.0780	1T	6.0 0.0 0.0	11.600 6.000 17.600	45.361 0.0 1.372			Vel = 6.69	
	0.0 31.21					46.733			K Factor = 4.57	
6B to 12B	81.41 81.41	2.157 120.0 0.0521		0.0 0.0 0.0	10.700 0.0 10.700	46.175 0.0 0.558			Vel = 7.15	
12B to 13B	31.21 112.62	2.157 120.0 0.0951	1S 1T 1V 1X	13.537 12.307 4.307 10.461	55.750 47.996 103.746	46.733 22.490 9.869			* Fixed loss = 3 Vel = 9.89	

Final Calculations - Hazen-Williams

High Tech Fire Protection
Schlotterbeck Block

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
			1B 1Fsp	7.384 0.0					
13B to 11	0.0 112.62	4.26 120.0 0.0034	1V	8.954 0.0 0.0	45.000 8.954 53.954	79.092 0.0 0.186		Vel = 2.54	
11 to TOR	0.0 112.62	4.26 120.0 0.0035	6V	53.722 0.0 0.0	63.000 53.722 116.722	79.278 3.032 0.404		Vel = 2.54	
TOR to BOR	0.0 112.62	4.26 120.0 0.0034	1Fsp 1V	0.0 8.954 0.0	8.000 8.954 16.954	82.714 3.000 0.058		* Fixed loss = 3 Vel = 2.54	
BOR to UG0	0.0 112.62	4.26 120.0 0.0036	1Zia	0.0 0.0 0.0	5.000 0.0 5.000	85.772 3.501 0.018		* Fixed loss = 3.501 Vel = 2.54	
UG0 to UG1	0.0 112.62	6.16 140.0 0.0004	1G 1T	4.304 43.037 0.0	25.000 47.341 72.341	89.291 0.0 0.031		Vel = 1.21	
UG1 to UG2	0.0 112.62	8.27 140.0 0.0001	3T	166.063 0.0 0.0	550.000 166.063 716.063	89.322 0.0 0.074		Vel = 0.67	
UG2 to TEST	0.0 112.62	6.16 140.0 0.0004	1G 1E	4.304 20.084 0.0	15.000 24.388 39.388	89.396 1.299 0.017		Vel = 1.21	
	100.00 212.62					90.712		Qa = 100.00 K Factor = 22.32	