



... Fire Protection by Computer Design

High Tech Fire Protection
84 Hackett Mills Rd
PO Box 156
Poland, ME, 04274
207-998-2551

Job Name : Schlotterbeck
Building : Fp-02
Location : Top Floor
System : 1
Contract :
Data File : Top Floor Calc.WXF

HYDRAULIC CALCULATIONS
for

Project name: Schlotterbeck
Location: Top Floor
Drawing no: Fp-02
Date: 4-6-2016

Design

Remote area number: 1
Remote area location: Top Floor
Occupancy classification: Light
Density: .1 - Gpm/SqFt
Area of application: 250 - SqFt
Coverage per sprinkler: 256 - SqFt
Type of sprinklers calculated: 4
No. of sprinklers calculated: 4
In-rack demand: - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 206.791 - GPM @ 102.038 - Psi
Type of system: NFPA 13
Volume of dry or preaction system: - Gal

Water supply information

Date: 10-28-2016
Location: Riser
Source: Main Riser Tag

Name of contractor: High Tech Fire Protection
Address: 84 Hackett Mills Rd / PO Box 156 / Poland, ME, 04274
Phone number: 207-998-2551
Name of designer: Ed Pennell
Authority having jurisdiction: Portland Fire Department
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve (C)

High Tech Fire Protection
Schlotterbeck

Page 2
Date

City Water Supply:
C1 - Static Pressure : 112
C2 - Residual Pressure: 108
C2 - Residual Flow : 1342

Demand:
D1 - Elevation : 28.152
D2 - System Flow : 106.791
D2 - System Pressure : 102.038
Hose (Demand) : 100
D3 - System Demand : 206.791
Safety Margin : 9.836



Fittings Used Summary

High Tech Fire Protection
Schlotterbeck

Page 3
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

High Tech Fire Protection
Schlotterbeck

Page 4
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	65.0	4.9	27.3	na	25.6	0.1	256	13.5
2	65.0	4.9	29.25	na	26.5	0.1	256	13.5
P*	0.0		55.45	na				
3	65.0	4.9	30.09	na	26.88	0.1	256	13.5
4	65.0	4.9	32.22	na	27.81	0.1	256	13.5
5	65.0		37.66	na				
6	65.0		45.18	na				
7	66.0		47.78	na				
8	66.0		48.46	na				
9	66.0		55.0	na				
10	10.0		90.25	na				
11	10.0		90.45	na				
TOR	3.0		93.85	na				
BOR	3.0		96.9	na				
UG0	3.0		100.63	na				
UG1	3.0		100.66	na				
UG2	3.0		100.72	na				
TEST	0.0		102.04	na	100.0			

The maximum velocity is 22.91 and it occurs in the pipe between nodes 5 and 6

Final Calculations - Hazen-Williams

High Tech Fire Protection
Schlotterbeck

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1 to 2	25.60 25.6	1.049 120.0 0.2055		0.0 0.0 0.0	9.500 0.0 9.500	27.295 0.0 1.952			K Factor = 4.90	
2 to 5	26.50 52.1	1.049 120.0 0.7649	1E	2.0 0.0 0.0	9.000 2.000 11.000	29.247 0.0 8.414			K Factor = 4.90	
	0.0 52.10					37.661			K Factor = 8.49	
3 to 4	26.88 26.88	1.049 120.0 0.2248		0.0 0.0 0.0	9.500 0.0 9.500	30.086 0.0 2.136			K Factor = 4.90	
4 to 5	27.81 54.69	1.049 120.0 0.8368	1T	5.0 0.0 0.0	1.500 5.000 6.500	32.222 0.0 5.439			K Factor = 4.90	
5 to 6	52.10 106.79	1.38 120.0 0.7590	1E	3.0 0.0 0.0	6.900 3.000 9.900	37.661 0.0 7.514				Vel = 22.91
6 to 7	0.0 106.79	1.38 120.0 0.7590	1E	3.0 0.0 0.0	1.000 3.000 4.000	45.175 -0.433 3.036				Vel = 22.91
7 to 8	0.0 106.79	1.38 120.0 0.7589		0.0 0.0 0.0	0.900 0.0 0.900	47.778 0.0 0.683				Vel = 22.91
8 to 9	0.0 106.79	1.61 120.0 0.3582	1T	8.0 0.0 0.0	10.250 8.000 18.250	48.461 0.0 6.538				Vel = 16.83
9 to 10	0.0 106.79	2.157 120.0 0.0862	1V 1T 1X 1B 1Fsp	4.307 12.307 10.461 7.384 0.0	58.250 34.459 92.709	54.999 27.254 7.993			* Fixed loss = 3	Vel = 9.38
10 to 11	0.0 106.79	4.26 120.0 0.0031	1V	8.954 0.0 0.0	56.000 8.954 64.954	90.246 0.0 0.204				Vel = 2.40
11 to TOR	0.0 106.79	4.26 120.0 0.0031	6V	53.722 0.0 0.0	63.000 53.722 116.722	90.450 3.032 0.365				Vel = 2.40
TOR to BOR	0.0 106.79	4.26 120.0 0.0031	1Fsp 1V	0.0 8.954 0.0	8.000 8.954 16.954	93.847 3.000 0.053			* Fixed loss = 3	Vel = 2.40
BOR to UG0	0.0 106.79	4.26 120.0 0.0032	1Zia	0.0 0.0 0.0	5.000 0.0 5.000	96.900 3.712 0.016			* Fixed loss = 3.712	Vel = 2.40
UG0 to UG1	0.0 106.79	6.16 140.0 0.0004	1G 1T	4.304 43.037 0.0	25.000 47.341 72.341	100.628 0.0 0.028				Vel = 1.15
UG1 to UG2	0.0 106.79	8.27 140.0 0.0001	3T	166.063 0.0 0.0	550.000 166.063 716.063	100.656 0.0 0.067				Vel = 0.64

Final Calculations - Hazen-Williams

High Tech Fire Protection
Schlotterbeck

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
UG2	0.0	6.16	1G 4.304	15.000	100.723				
to		140.0	1E 20.084	24.388	1.299				
TEST	106.79	0.0004	0.0	39.388	0.016		Vel = 1.15		
	100.00						Qa = 100.00		
	206.79				102.038		K Factor = 20.47		