



- ▲ Install new 24x24 egg crate return
Connect to existing flex duct
- ▲ Existing steam coil to be removed
Install duct spool piece and insulate
- ▲ Connect to supply drop
- ▲ Provide new supply and return drops
From new 4 ton RTU curb
- ▲ demo existing duct system
replace with all new
- ▲ ceiling to be removed
suspend diffusers reset in new grid
- ▲ Relocated existing diffuser

Lower roof

TENANT 1

KITCHENETTE

SKYLIGHT

190 Lancaster 3rd fl

DUCT PLAN



M2