

PERMIT ISSUED

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 06-0048	Issue Date: FEB - 3 2006	CBL: 033 1002001
-----------------------	-----------------------------	---------------------

Location of Construction: 27 PARRIS ST	Owner Name: CLOUTIER TOOTHAKER ASSOC	Owner Address: P.O. BOX 427 STATION A CITY OF PORTLAND	Phone: 2072524222
Business Name:	Contractor Name: Fournier Brothers Mechanical	Contractor Address: 85 Oakdale Street Portland	Phone: 2072524222
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	Zone:

5 unit Condo	5 unit Condo - install a Weil Mclain SGO - oil boiler- & Weil Mclain CGA - Gas fired	\$66.00	\$5,000.00	1
		FIRE DEFT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied <i>TO NFPA 31 + 54</i>	INSPECTION: Use Group <i>HVAC</i> Type <i>IMC 2003/State Code</i>	
		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied		
		Signature: _____ Date: _____		

Permit Taken By: Idobson	Date Applied For: 01/10/2006	Zoning Approval	
-----------------------------	---------------------------------	------------------------	--

<ol style="list-style-type: none"> This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. Building permits do not include plumbing, septic or electrical work. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.. 	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date: <i>2/2/06</i>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date: _____	Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmar <input checked="" type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: <i>2/2/06</i>
---	---	---	--

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.


SIGNATURE OF APPLICANT ADDRESS DATE PHONE

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE DATE PHONE



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 33I2 Use of Building Sun + Date 1/10/04
 Name and address of owner of appliance Toothaker
Davis St.
 Installer's name and address Fournier Bros. Mechanical
85 Oakdale St. Portland 04103 Telephone 252-222

Location of appliance:

- Basement Floor
 Attic Roof

Type of Fuel:

- Gas Oil Solid

Appliance Name ① Weil M=Chain SGO-oil boiler
① Weil M=Chain CGA-gas fired

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
 Solid Fuel # _____
 Oil # 7317
 Gas # 1032
 Other _____

Type of Chimney:

- Masonry Lined
 Factory built Clay-tile liner

- Metal
 Factory Built U.L. Listing # _____

- Direct Vent
 Type _____ uL# _____

Type of Fuel Tank

- Oil
 Gas

Size of Tank 275

Number of Tanks ①

Distance from Tank to Center of Flame 5+ feet.

Cost of Work: \$ 5,000

Permit Fee: \$ 166.00

Approved

Approved with Conditions

Fire: _____
 Ele.: _____
 Bldg.: _____

- See attached letter or requirement

Signature of Installer [Signature] Inspector's Signature _____ Date Approved _____

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 06-0048	Date Applied For: 0111012006	CBL: 033 I002001
------------------------------	--	----------------------------

Location of Construction: 27 PARRIS ST	Owner Name: CLOUTIER TOOTHAKER ASSOC	Owner Address: P.O. BOX 4271 STATION A	Phone:
Business Name:	Contractor Name: Fournier Brothers Mechanical	Contractor Address: 85 Oakdale Street Portland	Phone (207) 252-4222
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	

Proposed Use: 5 unit Condo - install a Weil Mclain SGO - oil boiler- & Weil Mclain CGA - Gas fired	Proposed Project Description: Install a Weil Mclain SGO - oil boiler- & Weil Mclain CGA - Gas fired
--	---

Dept: Zoning **Status:** Approved **Reviewer:** Tammy Munson **Approval Date:** 02/02/2006
Note: **Ok to Issue:**

Dept: Building **Status:** Approved with Conditions **Reviewer:** Tammy Munson **Approval Date:** 0210212006
Note: **Ok to Issue:**

- 1) The installation must comply with the State of Maine Gas Regulations.
- 2) Installation shall comply with 2003 International Mechanical Code and State of Maine Oil and Solid Fuel Board Laws and Rules

Dept: Fire **Status:** Approved with Conditions **Reviewer:** Cptn Greg Cass **Approval Date:** 01/11/2006
Note: **Ok to Issue:**

- 1) Gas fired boiler to comply with NFPA 54
- 2) Oil fired boiler to comply with nfpa 31