

DATE: 12/10/86
 ADDRESS: 8 Hanover Street
 REASON FOR PERMIT: Change of dwelling units
 BUILDING OWNER: 8-12 Hanover
 CONTRACTOR: Daabrie/Pizza
 PERMIT APPLICANT: Joe Pizza
 APPROVED: 123456 - DENIED

CONDITION OF APPROVAL OR DENIAL:

- 1.) All vertical openings shall be enclosed fire rating of at least one(1) hour, in self-closers.
- 2.) Each apartment shall have access to two approved means of egress. A single exit exists directly from the apartment to the communications to other apartment units.
- 3.) Each apartment shall be equipped with a smoke detector powered by the house circuit located in an area which will provide pressure.
- 4.) The boiler shall be protected by enclosed rated construction including fire doors over the boiler, two(2) residential size the domestic water.
- 5.) Every sleeping room below the fourth floor Groups R and I-1 shall have at least one exterior door approved for emergency egress must be operable from the inside opening separate tools. Where windows are provided for rescue, they shall have a sill height 44 inches (1118 mm) above the floor. All egress or rescue rooms must have minimum net clear opening (0.53m²). The minimum net clear opening shall be 24 inches (610 mm). The minimum net clear opening shall be 20 inches (508 mm).



Certificate of Occupancy

CITY OF PORTLAND, MAINE
 Department of Building Inspection
 LOCATION: 8 Hanover Street

Issued to Darbacia/Plano Development
 This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. 86/1768, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

APPROVED OCCUPANCY
 2 units
 Limiting Conditions:
Additional 3rd Floor

This certificate supersedes certificate issued 5-17-86
 Approved: William Lane
 Inspector
 Date of Issue: May 27, 1987

Notes: This certificate identifies building use of building or premises. It is subject to the provisions of the City Code of Ordinances, Chapter 21A, and the provisions of the Maine Building Code. Any other use or occupancy not shown on this certificate is prohibited. Any other use or occupancy not shown on this certificate is prohibited.