

Legalization Inspection Form

Date: 10/4/17

Address: 38 Portland Street

Legal Use: First floor Retail, Second floor one dwelling unit

Proposed Use: \_\_\_\_\_

Common Areas Units need to be numbered or identified  
Fire extinguishers need to be inspected and tagged

**Basement**

- o Fire Door: Needs to close securely -
- o Detection: \_\_\_\_\_
- o Sprinkler Head: Boiler protection needed
- o Electrical/panel: Terminated wires need to be removed

Notes: \_\_\_\_\_

**Unit 1** (commercial space)

- o Fire Door: 60 minute fire door needs to be installed
- o Detection: \_\_\_\_\_
- o Egress: \_\_\_\_\_

Notes: False or terminated stairway needs to be enclosed  
or eliminated

**Unit 2**

- o Fire Door: \_\_\_\_\_
- o Detection: \_\_\_\_\_
- o Egress: \_\_\_\_\_

Notes: Sink and stove in bedroom unit need to be removed

Unit \_\_\_\_\_

- Fire Door: \_\_\_\_\_
- Detection: \_\_\_\_\_
- Egress: \_\_\_\_\_

Notes: \_\_\_\_\_

Unit \_\_\_\_\_

- Fire Door: \_\_\_\_\_
- Detection: \_\_\_\_\_
- Egress: \_\_\_\_\_

Notes: \_\_\_\_\_

Unit \_\_\_\_\_

- Fire Door: \_\_\_\_\_
- Detection: \_\_\_\_\_
- Egress: \_\_\_\_\_

Notes: \_\_\_\_\_

Unit \_\_\_\_\_

- Fire Door: \_\_\_\_\_
- Detection: \_\_\_\_\_
- Egress: \_\_\_\_\_

Notes: \_\_\_\_\_

Overall Pass \_\_\_\_\_ Fail  Follow up Required

Inspector: Charles Koyan

Fire Prevention: David Felumcell