

Sequence of Operations

Manual Pull Stations	X	X	X	X	X	X	X													X	A	
Smoke detectors common area	X	X	X	X	X	X	X						X	X	X					X	A	
Smoke detectors elevator lobbies	X	X	X	X	X	X	X						X	X	X					X	A	
Smoke Detectors elevator shaft/machine room	X	X	X	X	X	X	X			X	X										A	
Duct mounted Smoke Detectors				X	X	X	X														S	X
Heat Detectors common area/inside apartments	X	X	X	X	X	X	X														A	
Heat Detectors Elevator shaft/machine room	X	X	X	X	X	X	X		X												A	
CO Detection	X	X	X	X	X	X	X														S	
Sprinkler flow or pressure switches	X	X	X	X	X	X	X														A	
Sprinkler Tamper, low temp, or low air				X	X	X	X														S	
Secondary fire panel such as kitchen hood	X	X	X	X	X	X	X														A	
FACP/annunciator silence button		X	X	X	X	X	X														L	
FACP/annunciator acknowledge button		X	X	X	X	X	X														L	
FACP/annunciator reset button		X	X	X	X	X	X														L	
Removal of any device		X	X	X	X	X	X														T	
Ground fault		X	X	X	X	X	X														T	
System wiring "open"		X	X	X	X	X	X														T	
AC Power loss		X	X	X	X	X	X														T	
Secondary power loss		X	X	X	X	X	X														T	
Telephone line loss		X	X	X	X	X	X														T	