

•  
•  
•  
•  
•  
•  
•

389 Congress St.Rm 315  
Portland, ME 04101  
Phone: (207)874-8700  
Fax: (207)874-8716

# facsimile transmittal


**To:** James Sterling **From:** Mike Nugent

**Fax:** 773-8545 **Date:** September 30, 2002

**Phone:** **Pages:** 1

**Re:** 343 Cumberland Ave. (033-K004)

Urgent     For Review     Please Comment     Please Reply     Please Recycle



•    •    •    •    •    •    •    •  
I have commenced the review of the above project and have the following questions:

- 1) Pursuant to Section 602, what type of construction is the building?
- 2) Please provide a code justification for the new windows on the East Side of the building, See Section 705 of the 1999 BOCA Code.
- 3) Please provide occupant loads for the communal room (102) and Preble St. room (139)
- 4) Is a local Exhaust System required for the Kitchen?
- 5) Is a grease trap?
- 6) Upper level, rooms 146, upper hall etc. seem to exceed the limitations of Section 1011.2 Dead Ends.
- 7) Similarly on the Lower level, Is the "storage hall" an exit access?

• • • • •