

# Protection Professionals

## FIRE ALARM AND EMERGENCY COMMUNICATION SYSTEM

### RECORD OF COMPLETION - Add on

#### 1. PROPERTY INFORMATION

Name of property: Youth Family  
Address: 331 Cumberland Ave Portland ME 04102  
Description of property: 2 Level day care  
Occupancy type: Day care  
Name of property representative:  
Address:  
Phone: Fax: E-mail:  
Authority having jurisdiction over this property: Portland Fire Department  
Phone: 207-874-8576 Fax: E-mail:

#### 2. INSTALLATION, SERVICE, AND TESTING CONTRACTOR INFORMATION

Installation contractor for this equipment: ~~Protection Professionals~~ Tuom: Electric  
Address: ~~325 US Route One, Falmouth, ME 04106~~ 42 Strawberry Hill Lane Harrison ME 04040  
License or certification number:  
Phone: ~~207-775-5755~~ <sup>207-525-0051</sup> Fax: ~~207-781-2064~~ E-mail: ~~mail@protectionprofessionals.net~~  
Service organization for this equipment: Protection Professionals  
Address: 325 US Route One, Falmouth, ME 04106  
License or certification number:  
Phone: 207-775-5755 Fax: 207-781-2064 E-mail: mail@protectionprofessionals.net  
A contract for test and inspection in accordance with NFPA standards is in effect as of:  
Contracted testing company:  
Address:  
Phone: Fax: E-mail:  
Contract expires: Contract number: Frequency of routine inspections: / Year

#### 3. DESCRIPTION OF SYSTEM OR SERVICE

- Fire alarm system (nonvoice)  
 Fire alarm with in-building fire emergency voice alarm communication system (EVACS)  
 Mass notification system (MNS)  
 Combination system, with the following components:  
 Fire alarm  EVACS  MNS  Two-way, in-building, emergency communication system  
 Other (specify):

# Protection Professionals

## 3. DESCRIPTION OF SYSTEM OR SERVICE (continued)

NFPA 72 edition: **2010** Additional description of system(s):

### 3.1 Control Unit

Manufacturer: **ADAMCO**

Model number: **Vista 128**

### 3.2 Mass Notification System

This system does not incorporate an MNS

#### 3.2.1 System Type:

In-building MNS—combination

In-building MNS—stand-alone

Wide-area MNS

Distributed recipient MNS

Other (specify):

#### 3.2.2 System Features:

Combination fire alarm/MNS

MNS autonomous control unit

Wide-area MNS to regional national alerting interface

Local operating console (LOC)

Direct recipient MNS (DRMNS)

Wide-area MNS to DRMNS interface

Wide-area MNS to high-power speaker array (HPSA) interface

In-building MNS to wide-area MNS interface

Other (specify):

### 3.3 System Documentation

An owner's manual, a copy of the manufacturer's instructions, a written sequence of operation, and a copy of the numbered record drawings are stored on site. Location: **NOT FOUND**

### 3.4 System Software

This system does not have alterable site-specific software.

Operating system (executive) software revision level:

Site-specific software revision date:

Revision completed by:

A copy of the site-specific software is stored on site. Location: **NOT FOUND**

### 3.5 Off-Premises Signal Transmission

This system does not have off-premises transmission.

Name of organization receiving alarm signals with phone numbers:

Alarm: **Cunningham Security** Phone: **1-207-878-5858**

Supervisory: **Cunningham Security** Phone: **1-207-878-5858**

Trouble: **Cunningham Security** Phone: **1-207-878-5858**

Entity to which alarms are retransmitted: **Portland Fire Dispatch** Phone: **207-874-8576**

Method of retransmission: **Phone**

If Chapter 26, specify the means of transmission from the protected premises to the supervising station:

If Chapter 27, specify the type of auxiliary alarm system:  Local energy  Shunt  Wired  Wireless

# Protection Professionals

## 4. CIRCUITS AND PATHWAYS

### 4.1 Signaling Line Pathways

#### 4.1.1 Pathways Class Designations and Survivability

Pathways class:

Survivability level:

Quantity:

(See NFPA 72, Sections 12.3 and 12.4)

ADD ON  
0

#### 4.1.2 Pathways Utilizing Two or More Media

Quantity:

Description:

#### 4.1.3 Device Power Pathways

- No separate power pathways from the signaling line pathway
- Power pathways are separate but of the same pathway classification as the signaling line pathway
- Power pathways are separate and different classification from the signaling line pathway

#### 4.1.4 Isolation Modules

Quantity:

0

### 4.2 Alarm Initiating Device Pathways

#### 4.2.1 Pathways Class Designations and Survivability

Pathways class:

Survivability level:

Quantity:

(See NFPA 72, Sections 12.3 and 12.4)

used  
1 existing & added

#### 4.2.2 Pathways Utilizing Two or More Media

Quantity:

Description:

#### 4.2.3 Device Power Pathways

- No separate power pathways from the initiating device pathway
- Power pathways are separate but of the same pathway classification as the initiating device pathway
- Power pathways are separate and different classification from the initiating device pathway

### 4.3 Non-Voice Audible System Pathways

#### 4.3.1 Pathways Class Designations and Survivability

Pathways class:

Survivability level:

Quantity:

(See NFPA 72, Sections 12.3 and 12.4)

added used existing

#### 4.3.2 Pathways Utilizing Two or More Media

Quantity:

Description:

#### 4.3.3 Device Power Pathways

- No separate power pathways from the notification appliance pathway
- Power pathways are separate but of the same pathway classification as the notification appliance pathway
- Power pathways are separate and different classification from the notification appliance pathway

# Protection Professionals

## 5. ALARM INITIATING DEVICES

### 5.1 Manual Initiating Devices

#### 5.1.1 Manual Fire Alarm Boxes

This system does not have manual fire alarm boxes.

Type and number of devices: Addressable:

Conventional: *0 added*

Coded: Transmitter:

Other (specify):

#### 5.1.2 Other Alarm Boxes

This system does not have other alarm boxes.

Description:

Type and number of devices: Addressable:

Conventional:

Coded:

Transmitter:

Other (specify):

### 5.2 Automatic Initiating Devices

#### 5.2.1 Smoke Detectors

This system does not have smoke detectors.

Type and number of devices: Addressable:

Conventional: *4 added*

Other (specify):

Type of coverage:  Complete area  Partial area  Nonrequired partial area

Other (specify):

Type of smoke detector sensing technology:  Ionization  Photoelectric  Multicriteria  Aspirating  Beam

Other (specify):

#### 5.2.2 Duct Smoke Detectors

This system does not have alarm-causing duct smoke detectors.

Type and number of devices: Addressable:

Conventional:

Other (specify):

Type of coverage:

Type of smoke detector sensing technology:  Ionization  Photoelectric  Aspirating  Beam

#### 5.2.3 Radiant Energy (Flame) Detectors

This system does not have radiant energy detectors.

Type and number of devices: Addressable:

Conventional:

Other (specify):

Type of coverage:

#### 5.2.4 Gas Detectors

This system does not have gas detectors.

Type of detector(s):

Number of devices: Addressable:

Conventional:

Type of coverage:

#### 5.2.5 Heat Detectors

This system does not have heat detectors.

Type and number of devices: Addressable:

Conventional: *1 added*

Type of coverage:  Complete area  Partial area  Nonrequired partial area  Linear  Spot

Type of heat detector sensing technology:  Fixed temperature  Rate-of-rise  Rate compensated

# Protection Professionals

## 5. ALARM INITIATING DEVICES (continued)

### 5.2.6 Addressable Monitoring Modules

This system does not have monitoring modules.

Number of devices:

### 5.2.7 Waterflow Alarm Devices

This system does not have waterflow alarm devices.

Type and number of devices: Addressable: Conventional: Coded: Transmitter:

### 5.2.8 Alarm Verification

This system does not incorporate alarm verification.

Number of devices subject to alarm verification: Alarm verification set for: seconds

### 5.2.9 Presignal

This system does not incorporate pre-signal.

Number of devices subject to presignal:

Describe presignal functions:

### 5.2.10 Positive Alarm Sequence (PAS)

This system does not incorporate PAS.

Describe PAS:

### 5.2.11 Other Initiating Devices

This system does not have other initiating devices.

Describe:

## 6. SUPERVISORY SIGNAL-INITIATING DEVICES *None added*

### 6.1 Sprinkler System Supervisory Devices

This system does not have sprinkler supervisory devices.

Type and number of devices: Addressable: Conventional: Coded: Transmitter:

Other (specify):

### 6.2 Fire Pump Description and Supervisory Devices

This system does not have a fire pump.

Type fire pump:  Electric pump  Engine

Type and number of devices: Addressable: Conventional: Coded: Transmitter:

Other (specify):

#### 6.2.1 Fire Pump Functions Supervised

Power  Running  Phase reversal  Selector switch not in auto  Engine or control panel trouble  Low fuel

Other (specify):

### 6.3 Duct Smoke Detectors (DSDs)

This system does not have DSDs causing supervisory signals.

Type and number of devices: Addressable: Conventional:

Other (specify):

Type of coverage:

Type of smoke detector sensing technology:  Ionization  Photoelectric  Aspirating  Beam

### 6.4 Other Supervisory Devices

This system does not have other supervisory devices.

Describe:

# Protection Professionals

*non added*

## 7. MONITORED SYSTEMS

### 7.1 Engine-Driven Generator

This system does not have a generator.

#### 7.1.1 Generator Functions Supervised

Engine or control panel trouble     Generator running     Selector switch not in auto     Low fuel

Other (specify):

### 7.2 Special Hazard Suppression Systems

This system does not monitor special hazard systems.

Description of special hazard system(s):

### 7.3 Other Monitoring Systems

This system does not monitor other systems.

Description of special hazard system(s):

## 8. ANNUNCIATORS

This system does not have annunciators.

### 8.1 Location and Description of Annunciators

Location 1: *LCD Side Entrance*

Location 2:

Location 3:

## 9. ALARM NOTIFICATION APPLIANCES

### 9.1 In-Building Fire Emergency Voice Alarm Communication System

This system does not have an EVACS.

Number of single voice alarm channels:

Number of multiple voice alarm channels:

Number of speakers:

Number of speaker circuits:

Location of amplification and sound-processing equipment:

Location of paging microphone stations:

Location 1:

Location 2:

Location 3:

### 9.2 Nonvoice Notification Appliances

This system does not have nonvoice notification appliances.

Horns:                      With visible:

Bells:                      With visible:

Chimes:                      With visible:

Visible only: *2 added* Other (describe):

### 9.3 Notification Appliance Power Extender Panels

This system does not have power extender panels.

Quantity: *2 added*

Locations:

# Protection Professionals

## 10. MASS NOTIFICATION CONTROLS, APPLIANCES, AND CIRCUITS This system does not have an MNS.

### 10.1 MNS Local Operating Consoles

Location 1:

Location 2:

Location 3:

### 10.2 High-Power Speaker Arrays

Number of HPSA speaker initiation zones:

Location 1:

Location 2:

Location 3:

### 10.3 Mass Notification Devices

Combination fire alarm/MNS visible appliances:

MNS-only visible appliances:

Textual signs:

Other (describe):

Supervision class:

#### 10.3.1 Special Hazard Notification

This system does not have special suppression predischage notification.

MNS systems DO NOT override notification appliances required to provide special suppression predischage notification.

## 11. TWO-WAY EMERGENCY COMMUNICATION SYSTEMS

### 11.1 Telephone System

This system does not have a two-way telephone system.

Number of telephone jacks installed:

Number of warden stations installed:

Number of telephone handsets stored on site:

Type of telephone system installed:  Electrically powered  Sound powered

### 11.2 Two-Way Radio Communications Enhancement System

This system does not have a two-way radio communications enhancement system.

Percentage of area covered by two-way radio service: Critical areas: % General building areas: %

Amplification component locations:

Inbound signal strength: dBm Outbound signal strength: dBm

Donor antenna isolation is: dB above the signal booster gain

Radio frequencies covered:

Radio system monitor pannel location:

# Protection Professionals

## 11. TWO-WAY EMERGENCY COMMUNICATION SYSTEMS *(continued)*

### 11.3 Area of Refuge (Area of Rescue Assistance) Emergency Communications Systems

This system does not have an area of refuge (area of rescue assistance) emergency communications system.

Number of stations: \_\_\_\_\_ Location of central control point: \_\_\_\_\_

Days and hours when central control point is attended: \_\_\_\_\_

Location of alternate control point: \_\_\_\_\_

Days and hours when alternate control point is attended: \_\_\_\_\_

### 11.4 Elevator Emergency Communications Systems

This system does not have an elevator emergency communications system.

Number of elevators with stations: \_\_\_\_\_ Location of central control point: \_\_\_\_\_

Days and hours when central control point is attended: \_\_\_\_\_

Location of alternate control point: \_\_\_\_\_

Days and hours when alternate control point is attended: \_\_\_\_\_

### 11.5 Other Two-Way Communication Systems

Describe: \_\_\_\_\_

## 12. CONTROL FUNCTIONS

This system activates the following control functions: *non added*

- Hold-open door releasing devices     Smoke management     HVAC shutdown     F/S dampers  
 Door unlocking     Elevator recall     Fuel source shutdown     Extinguishing agent release  
 Elevator shunt trip     Mass notification system override of fire alarm notification appliances

Other (specify): \_\_\_\_\_

### 12.1 Addressable Control Modules

This system does not have control modules.

Number of devices: \_\_\_\_\_

Other (specify): \_\_\_\_\_

## 13. SYSTEM POWER

### 13.1 Control Unit *not changed*

#### 13.1.1 Primary Power

Input voltage of control panel: \_\_\_\_\_

Control panel amps: \_\_\_\_\_

Overcurrent protection: \_\_\_\_\_ Type: \_\_\_\_\_

Amps: \_\_\_\_\_

Location (of primary supply panel board): \_\_\_\_\_

Disconnecting means location: \_\_\_\_\_

#### 13.1.2 Engine-Driven Generator

This system does not have a generator.

Location of generator: \_\_\_\_\_

Location of fuel storage: \_\_\_\_\_

Type of fuel: \_\_\_\_\_

AF-113 (Rev. 10/10) NFPA 720



# Protection Professionals

## 13. SYSTEM POWER (continued)

### 13.1.3 Uninterruptible Power System

This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours):

In alarm mode (minutes):

### 13.1.4 Batteries

Location: *in panel* Type: *SLA* Nominal voltage: *12V X 2* Amp/hour rating: *7*

Calculated capacity of batteries to drive the system:

In standby mode (hours):

In alarm mode (minutes):

Batteries are marked with date of manufacture  Battery calculations are attached

### 13.2 In-Building Fire Emergency Voice Alarm Communication System or Mass Notification System

This system does not have an EVACS or MNS system.

#### 13.2.1 Primary Power

Input voltage of EVACS or MNS panel:

EVACS or MNS panel amps:

Overcurrent protection: Type:

Amps:

Location (of primary supply panel board):

Disconnecting means location:

#### 13.2.2 Engine-Driven Generator

This system does not have a generator.

Location of generator:

Location of fuel storage:

Type of fuel:

#### 13.2.3 Uninterruptible Power System

This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours):

In alarm mode (minutes):

#### 13.2.4 Batteries

Location:

Type:

Nominal voltage:

Amp/hour rating:

Calculated capacity of batteries to drive the system:

In standby mode (hours):

In alarm mode (minutes):

Batteries are marked with date of manufacture  Battery calculations are attached

2009-11-10 10:10:10

# Protection Professionals

## 13. SYSTEM POWER (continued)

### 13.3 Notification Appliance Power Extender Panels

This system does not have power extender panels.

#### 13.3.1 Primary Power

Input voltage of power extender panel(s):

Power extender panel amps:

Overcurrent protection: Type:

Amps:

Location (of primary supply panel board):

Disconnecting means location:

#### 13.3.2 Engine-Driven Generator

This system does not have a generator.

Location of generator:

Location of fuel storage:

Type of fuel:

#### 13.3.3 Uninterruptible Power System

This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours):

In alarm mode (minutes):

#### 13.3.4 Batteries

Location:

Type:

Nominal voltage:

Amp/hour rating:

Calculated capacity of batteries to drive the system:

In standby mode (hours):

In alarm mode (minutes):

Batteries are marked with date of manufacture

Battery calculations are attached

## 14. RECORD OF SYSTEM INSTALLATION

Fill out after all installation is complete and wiring has been checked for opens, shorts, ground faults, and improper branching, but before conducting operational acceptance tests.

This is a:  New system  Modification to an existing system Permit number:

The system has been installed in accordance with the following requirements: (Note any or all that apply.)

NFPA 72, Edition: 2010

NFPA 70, National Electrical Code, Article 760, Edition: 2011

Manufacturer's published instructions

Other (specify):

System deviations from referenced NFPA standards:

Signed:

Printed name: CHIP TUOMI

Date:

Organization: TUOMI ELECTRIC

Title:

Phone: 207 595 0051

# Protection Professionals

## 15. RECORD OF SYSTEM OPERATIONAL ACCEPTANCE TEST

New system

All operational features and functions of this system were tested by, or in the presence of, the signer shown below, on the date shown below, and were found to be operating properly in accordance with the requirements for the following:

Modifications to an existing system

All newly modified operational features and functions of the system were tested by, or in the presence of, the signer shown below, on the date shown below, and were found to be operating properly in accordance with the requirements of the following.


NFPA 72, Edition: 2010

NFPA 70, National Electrical Code, Article 760, Edition: 2011

Manufacturer's published instructions

Other (specify):


Individual device testing documentation [Inspection and Testing Form (Figure 14.6.2.4) is attached]

Signed:  Printed name: Byron Davis Date: 9-13-13  
Organization: Protection Professionals Title: Tech Phone: 207-775-5755

## 16. CERTIFICATIONS AND APPROVALS


### 16.1 System Installation Contractor:

This system, as specified herein, has been installed and tested according to all NFPA standards cited herein.

Signed:  Printed name: Chip Tuomi Date: 9/13/13  
Organization: Tuomi Electric Title: Owner Phone: 207-595-0051


### 16.2 System Service Contractor:

The undersigned has a service contract for this system in effect as of the date shown below.

Signed:  Printed name: Chip Tuomi Date: 9/13/13  
Organization: Tuomi Electric Title: Owner Phone: 207-595-0051

### 16.3 Supervising Station:

This system, as specified herein, will be monitored according to all NFPA standards cited herein.


Signed:  Printed name: Chip Tuomi Date: 9/13/13  
Organization: Tuomi Electric Title: Owner Phone: 207-595-0051

# Protection Professionals

## 16. CERTIFICATIONS AND APPROVALS (continued)

### 16.4 Property or Owner Representative:

This system, as specified herein, will be monitored according to all NFPA standards cited herein.

Signed:  Printed name: VALEKIE Date: 9/13/13  
Organization: GREAT FALLS Title: PARQUIN-GOULD Phone: 207-615-3034  
CONSTRUCTION Project Manager  
16.5 Authority Having Jurisdiction:

I have witnessed a satisfactory acceptance test of this system and find it to be installed and operating properly in accordance with its approved plans and specifications, with its approved sequence of operations, and with all NFPA standards cited herein.

Signed: Printed name: Date:  
Organization: Title: Phone:

NOTES: This Add on consisted of 4 smokes, 7 Heat,  
and 2 strobes. only added devices were tested.

# Protection Professionals

## DEVICE TEST RESULTS

(Attach additional sheets if required)

Device Type	Address	Location	Pass / Fail
SMOKE	zone 1	2nd floor Hall	PASS
SMOKE	zone 1	2nd floor Hall	PASS
SMOKE	zone 1	OFFICE 2nd floor	PASS
SMOKE	zone 1	CLASS ROOM 1 2nd floor	PASS
Heat	zone 1	2nd floor Bathroom	PASS
Strobe	NAC 1	2nd floor Bathroom	PASS
Strobe	NAC 1	2nd floor CLASS ROOM 2	PASS