

CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
 389 Congress Street
 Portland, Maine 04101

Inspection Violations

Owner/Manager Bae Hwa Sun		Inspector Suzanne Hunt	Inspection Date 10/25/2007
Locatation 349 CUMBERLAND AVE	CBL 033 K011001	Status	Inspection Type Food Service-Food Service Inspe

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 12-79	Exterior			BackYard	
Violation: Junk Vehicles					
Notes: Trailor located in back driveway must be removed. Dead Storage.					

Comments: ali 699-8876. Consultnt Andrew Juris, not an attorney, Plubing incorrect, leaking pipes, no air gap on prep sink. Beer bottle and two water bottles in ice container. Requested test strips be on iste and plumbing repaired. Smh Juris said he wowuld contact owner of trailer to remove. Smh