Portland Maine Yes. Google's good here.

Glenn Harmon <gharmon@portlandr

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/03/17

63 Preble St

1 message

Brian Laderbush <bladerbush@e4harchitecture.com> Mon, Oct 9, 2017 at 3:57 PM
To: "gharmon@portlandmaine.gov" <gharmon@portlandmaine.gov>
Cc: "bbrooks@boulos.com" <bbrooks@boulos.com>, "johler@hecallahan.com" <johler@hecallahan.com>, Charles Rizza <crizza@e4harchitecture.com>, "atucker@greaterportlandhealth.com" <atucker@greaterportlandhealth.com>

Good afternoon Glen,

See our response to your comments belo1 .

Let us kno1 if you have any other questions.

Item #1 (soiled holding rating):

Although a rating is not required by code due to the lack of square footage of the space, 1 e chose to provide rated 1 alls and door as an additional measure of protection for the o1 ner.

Item#2 (Door pull dimension):

The clearance currently measures 1'-2".

E4H 1 ill adjust the door to a 3'-0" door 1 hich 1 ill allo1 for 1'-8" clearance on the pull side (exceeding the 1'-6" ADA minimum)

Thank you,

Brian Laderbush

healthcare designer

bladerbush@**e4h**architecture.com

e4h

e4h ENVIRONMENTS FOR HEALTH **ARCHITECTURE**

183 middle street, portland, maine 04101

888.781.8441 **t** 207.773.8841 **c** 207.415.7790 **e4h**architecture.com

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/03/17

This message has been scanned for mal1 are by Websense. 1 1 1 .1 ebsense.com

63Preble 4-A100 GLHReview1.pdf
259K