

- 3. UNLESS OTHERWISE NOTED, CONVENIENCE RECEPTACLES SHALL BE MOUNTED 18 INCHES AFF AND LIGHTING TOGGLE SWITCHES 48 INCHES AFF.
- LIGHTING TOGGLE SWITCHES SHALL BE COMMERCIAL SPECIFICATION GRADE, 120 VOLT, SIDE WIRED AS MANUFACTURED BY LEVITON, PASS & SEYMOUR, OR APPROVED EQUAL.
- CONVENIENCE RECEPTACLES SHALL BE COMMERCIAL SPECIFICATION GRADE UNLESS SHOWN OTHERWISE, GROUNDING TYPE, NEMA 5-20R, SIDE WIRED, AS MANUFACTURED BY LEVITON, PASS & SEYMOUR, OR APPROVED EQUAL.
- HOSPITAL GRADE RECEPTACLES SHALL BE FURNISHED AS SHOWN AS MANUFACTURED BY LEVITON, PASS & SEYMOUR OR APPROVED EQUAL.
- DEVICE COVERPLATES SHALL BE THERMOPLASTIC NYLON TYPE WITH IVORY FINISH IN ALL FINISHED SPACES.
  MECHANICAL ROOMS, ELECTRICAL ROOM, AND UTILITY ROOMS SHALL BE FURNISHED WITH BRUSHED STAINLESS STEEL
  COVERPLATES.
- UNLESS OTHERWISE NOTED ALL HOMERUNS FOR 15 OR 20A CIRCUITS SHALL BE 2 $\sharp$ 12AWG &  $\sharp$ 12 GND. HOMERUNS FED FROM 20A, 19 CIRCUITS IN EXCESS OF 100 FEET (FOR 120V CIRCUITS) OR 200 FEET (FOR 277V CIRCUITS) SHALL BE  $\sharp$ 10AWG. ALL WIRING SHALL BE COPPER.
- 10. CONDUIT SYSTEMS: EXPOSED INTERIOR CONDUITS SHALL BE ENT, 3/4" MINIMUM. PROPERLY SUPPORTED MC CABLE ASSEMBLES MAY BE LISED ABOVE CELLINGS AND IN WALLS. HOSPITAL GRADE WIRNED FOR NEW EXAM ROOMS SHALLED IN NOT THE MC CABLE ASSEMBLES AS MANACTURED BY SOUTHWIFE OR APPROVED EQUAL, AND INSTALLED IN ACCORDANCE WITH VARIONAL ELECTRICAL CODE 517.13 (A) AND 517.13 (B). FLEXIBLE LIQUIDITION CONDUIT WHIPS SHALL BE USED FOR CONNECTION TO VIBIRATINE COUNTEMN.

MorrisSwitzer
ENVIRONMENTS
FOR HEALTH
ARCHITECTURE
183 Lidde Steel, Delight
ORK BLIGHTON IP PORTLAND
BARNATON IP PORTLAND
BARNATION IP PORTLAND
BARNATION IP DATA

4 (1)





d Health Renovation

Greater Portland H

		-
ŧεν	/ DESCRIPTION	DATE
_		
_		
_		
_		
-		_
-		
-		
_		
	ISSUED FOR CONSTRUCTION	7.36-17
_		

E0.0