

CITY OF PORTLAND, MAINE
MEMORANDUM

TO: Doris Hohman

DATE: 2/19/88

FROM: Arthur Rowe, Code Enforcement Officer

SUBJECT: 65 Elm Street Code Requirements.

In order to change the use of the 3 Unit apartment house at 65 Elm Street to a 16 bed shelter, the following code deficiencies must be corrected:

Emergency lights, 8 fire doors, fire escape, 2 exit pull stations, 3 horn and light alarms, 6 automatic smoke detectors.

The total estimate is \$9,500.00 This dollar figure is a rough ball park estimate only.

cc: Cynthia Hoeh



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 63 Elm Street

Issued to Tom Cardento, Arrow Realty

Date of Issue July 7, 1988

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. 88/806, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

Adolescent Center

Limiting Conditions:

None

This certificate supersedes
certificate issued

Approved:

7/7/88
(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.