

# Memorandum

---

**To:** Gregory Ninow


**From:** Mike Nugent

**Date:** 2/18/2005

**Re:** 120 Preble St.

---

I have commenced the review of the plans and have the following questions:

- 1) Please provide HVAC, Plumbing and Electrical Plans, including a local exhaust system design, that comply with the 2003 IMC, 1999 NEC and the Maine State Plumbing Code.
  - 2) Please provide Stair details that include tread, riser, headroom and width dimensions.
  - 3) Please document the load capability of the floor system above the basement areas.
  - 4) Please review Chapter 8 of the IBC and provide applicable information with regard to interior finishes.
- 
- 