RA

SEATIN

TOTAL SQ

RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 06/19/13

BENCH SEATING 22" WIDE, 18" HIGH
FRAMED IN 2x4
SUPPORTED EVERY 4'
WRAPPED IN 1/2" PLY.

BACK WALL TO BE ATTACHED
TO EXISTING CONCRETE WALL

FLOOR: 2x4 16" ON CENTER 4' BLOCKING

FLOOR: FLOORING IS 3/4" THICK PLANKS.

SIDE WALLS:
2x4 Framing 16" ON CENTER

BACK WALL

2x4 FRAMING 16" ON CENTER
SIDE + BACK WALLS COVERED IN 1/2" PLY