DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

Located at

FURMAN JENNIFER V /Garrett Fitzgerald

114 Preble St (118)

PERMIT ID: 2013-01143 **ISSUE DATE:** 06/19/2013 **CBL:** 033 O001001

has permission to Revised Application: interior alterations - 57 sq.ft. raised seating area & 133 sq.ft. raised seating area - proposed 1200 sf deck to be built on separate permit in the future

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and	written permission procured
before this building or part the	reof is lathed or otherwise
clsoed-in. 48 HOUR NOTICE	E IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Jeanie Bourke

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning Restaurant

 Building Inspections
 Fire Department

 Use Group: A-2
 Type: 3B

 Assembly - Restaurant
 ENTIRE

 MUBEC/IBC 2009
 ENTIRE

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY) or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Framing Only Final - Commercial Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No:	Date Applied For:	CBL:			
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 87	74-8716	2013-01143	06/05/2013	033	O001001		
oposed Use: Proposed Project Description:							
Restaurant	11 1						
area & 133 sq.ft. raised seating area - proposed 1200 sf deck to built on separate permit in the future							
Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 06/10/2013							
Note: In the B-7 zone there are no minimum setbacks and 100% lot coverage. Ok to Issue: \checkmark							
Conditions:							
 This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval. 							
 This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work. 							
Dept: Building Status: Approved w/Conditions Re	eviewer:	Jeanie Bourke	Approval Da	te:	06/19/2013		
Note:				Ok to I	lssue: 🗹		
Conditions:							
1) It is recommended that the one step change in elevation be designated with marking or floor surface that contrasts with the adjacent floor.							
 Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 							
3) Permit approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.							
• •	eviewer:	Chris Pirone	Approval Da		06/18/2013		
Note:				Ok to I	ssue: 🗹		
Conditions:1) All outstanding code violations shall be corrected prior to final in	spection						
	ispection.						
 All construction shall comply with City Code Chapter 10. http://www.portlandmaine.gov/citycode/chapter010.pdf 							
 A separate Suppression System Permit is required for all new suppression systems or sprinkler work effecting more than 20 heads. This review does not include approval of sprinkler system design or installation. 							
4) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.							
5) Occupancies with an occupant load of 100 persons or more require panic hardware on all doors serving as a means of egress.							
6) Any Fire alarm or Sprinkler systems shall be reviewed by a licensed contractor(s) for code compliance.							
 Street addresses shall be marked on the structure and shall be as approved by the City E-911 Addressing Officer. Contact Michelle Sweeney at 874-8682 for further information. 							
8) Any cutting and welding done will require a Hot Work Permit from Fire Department.							
A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation							
10 Fire extinguishers are required per NFPA 1.							