

. . . Fire Protection by Computer Design

Residential Fire Protection
64 Daggett Hill Rd.
Greene, ME 04236
946-3473

Job Name : 200 Kennebec Street
Building : Metal Building
Location : New 2017 Warehouse-Retail Space
System : Wet
Contract : C17005
Data File : 200 Kennebec Strret-Retail Space-Hyd Calc.WXF

Hydraulic Design Information Sheet

Name - 200 Kennebec Street Bldg Date - 3/29/2017
 Location - New 2017 Warehouse-Retail Space
 Building - Metal Building System No. - Wet
 Contractor - Residential Fire Protection Contract No. - C17005
 Calculated By - T. Pray Drawing No. - 1 OF 1
 Construction: () Combustible (X) Non-Combustible Ceiling Height - Sloped
 Occupancy - Retail Space and Storage Warehouse

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 (X) 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation - 1057	System Type	Sprinkler/Nozzle
	Density - .2	(X) Wet	Make Viking
D	Area Per Sprinkler - 130	() Dry	Model VK300
E	Elevation at Highest Outlet - 11.0'	() Deluge	Size 1/2"
S	Hose Allowance - Inside -	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance -	() Other	Temp.Rat.155
G	Hose Allowance - Outside - 250		

N Note

Calculation Flow Required - 521.31 Press Required - 67.57 At Test
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 11/2/2016		Cap. -
T	Time of Test - N/A	Rated Cap.-	Elev.-
E	Static Press - 102	@ Press -	
R	Residual Press - 50	Elev. -	Well
	Flow - 1016		Proof Flow
S	Elevation - 1		

U
 P Location - Hydrants are located on Kennebec Street, See plot plan for more
 P informatioun
 L Source of Information - Portland Water District
 Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G
 E Horizontal Barriers Provided:


Water Supply Curve (C)

Residential Fire Protection
200 Kennebec Street

Page 2
Date 3/8/2017

City Water Supply:
C1 - Static Pressure : 102
C2 - Residual Pressure: 50
C2 - Residual Flow : 1016

Demand:
D1 - Elevation : 4.331
D2 - System Flow : 271.307
D2 - System Pressure : 67.577
Hose (Adj City) : _____
Hose (Demand) : 250
D3 - System Demand : 521.307
Safety Margin : 19.292



Fittings Used Summary

Residential Fire Protection
200 Kennebec Street

Page 3
Date 3/8/2017

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Pressure / Flow Summary - STANDARD

Residential Fire Protection
200 Kennebec Street

Page 4
Date 3/8/2017

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	11.0	5.6	21.56	na	26.0	0.2	130	7.0
2	11.0	5.6	21.76	na	26.12	0.2	130	7.0
3	11.0	5.6	22.49	na	26.56	0.2	130	7.0
4	11.0	5.6	24.05	na	27.46	0.2	130	7.0
5	11.0	5.6	26.77	na	28.97	0.2	130	7.0
6	11.0	5.6	21.9	na	26.21	0.2	130	7.0
7	11.0	5.6	22.11	na	26.33	0.2	130	7.0
8	11.0	5.6	22.85	na	26.77	0.2	130	7.0
9	11.0	5.6	24.43	na	27.68	0.2	130	7.0
10	11.0	5.6	27.19	na	29.2	0.2	130	7.0
50	11.0		42.16	na				
51	11.0		42.81	na				
TOR	11.0		53.67	na				
BOR	1.0		67.33	na				
TEST	1.0		67.58	na	250.0			

The maximum velocity is 19.66 and it occurs in the pipe between nodes 10 and 51

Final Calculations - Hazen-Williams

Residential Fire Protection
200 Kennebec Street

Page 5
Date 3/8/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1	26.00	1.682			9.500	21.556				
to		120			0.0	0.0				
2	26.0	0.0213			9.500	0.202				K Factor = 5.60
2	26.12	1.682			9.500	21.758				Vel = 3.75
to		120			0.0	0.0				
3	52.12	0.0767			9.500	0.729				K Factor = 5.60
3	26.56	1.682			9.500	22.487				Vel = 7.53
to		120			0.0	0.0				
4	78.68	0.1645			9.500	1.563				K Factor = 5.60
4	27.46	1.682			9.500	24.050				Vel = 11.36
to		120			0.0	0.0				
5	106.14	0.2863			9.500	2.720				K Factor = 5.60
5	28.97	1.682	1T	9.9	24.500	26.770				Vel = 15.33
to		120		0.0	9.900	0.0				
50	135.11	0.4474			34.400	15.389				K Factor = 5.60
	0.0									Vel = 19.51
	135.11					42.159				K Factor = 20.81
6	26.21	1.682			9.500	21.904				K Factor = 5.60
to		120			0.0	0.0				
7	26.21	0.0215			9.500	0.204				Vel = 3.78
7	26.33	1.682			9.500	22.108				K Factor = 5.60
to		120			0.0	0.0				
8	52.54	0.0780			9.500	0.741				Vel = 7.59
8	26.77	1.682			9.500	22.849				K Factor = 5.60
to		120			0.0	0.0				
9	79.31	0.1669			9.500	1.586				Vel = 11.45
9	27.68	1.682			9.500	24.435				K Factor = 5.60
to		120			0.0	0.0				
10	106.99	0.2905			9.500	2.760				Vel = 15.45
10	29.20	1.682	1T	9.9	24.500	27.195				K Factor = 5.60
to		120		0.0	9.900	0.0				
51	136.19	0.4540			34.400	15.618				Vel = 19.66
	0.0									
	136.19					42.813				K Factor = 20.81
50	135.11	2.635			13.000	42.159				
to		120			0.0	0.0				
51	135.11	0.0503			13.000	0.654				Vel = 7.95
51	136.20	2.635	2I	16.474	43.000	42.813				
to		120		0.0	16.474	0.0				
TOR	271.31	0.1825			59.474	10.856				Vel = 15.96
TOR	0.0	2.635	1Z	8.237	10.000	53.669				
to		120		0.0	8.237	10.331				* Fixed loss = 6
BOR	271.31	0.1825			18.237	3.329				Vel = 15.96
BOR	0.0	6.16	2L	25.822	40.000	67.329				
to		140	1G	4.304	73.163	0.0				
TEST	271.31	0.0022	1T	43.037	113.163	0.248				Vel = 2.92
	250.00									Qa = 250.00
	521.31					67.577				K Factor = 63.42

Final Calculations - Standard

Residential Fire Protection
200 Kennebec Street

Page 6
Date 3/8/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
-----------------------	--------------	----------------------	---------------------------	-------------------------	----------------	----------------	-------	-------	-------
