WAREHOUSE FOUNDATION PLAN

1/8"=1'-0"

THE EXISTING FOUNDATION IS TO REMAIN AND BE REUSED. NOTIFY ENGINEER IF ANY ADVERSE FOUNDATION CONDITION IS UNCOVERED.

DIMENSIONS ARE APPROXIMATE AND MUST BE FIELD VERIFIED. THE NEW BUILDING IS TO BE CONSTRUCTED FOLLOWING THE PERIMETER OF THE EXISTING BUILDING.

FIELD VERIFY ALL EXISTING FOUNDATION DIMENSIONS AND TOP OF CONCRETE ELEVATIONS.

TOP OF NEW SLAB ELEV TO MATCH TOP OF EXIST. SLAB ELEV.

SLAB-ON-GRADE IS 5" THICK WITH 6x6-W2.9xW2.9 WWF LOCATED 1 1/2" FROM THE TOP BEARING ON A 10 MIL POLY VAPOR BARRIER OVERLYING 8" OF COMPACTED STRUCTURAL FILL.

Project North

W E S

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/30/15

Prepared For:
Northland Enterprises, LLC
ONE CITY CENTER
PORTLAND, MAINE

Structural Engineer:
STRUCTURAL DESIGN CONSULTING
22 Oakmont Drive
Old Orchard Beach, ME
04064-4121
Tel 207.934.8038
Fax 207.934.8039

Architect:
ARCHETYPE architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056

Project:
CENTURY TIRE
815 MARGINAL WAY
PORTLAND, MAINE

Revisions:
Issued for Permit 03/16/15

Scale: 1/8" = 1'-0"

Date: 16 Mar 15

WAREOUSE
FOUNDATION PLAN

S1.2