


City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 155 Kennebec St		Owner: Aronson, Nick		Phone:		Permit No: 970729	
Owner Address:		Lessee/Buyer's Name: Century Tire		Phone:		Business Name:	
Contractor Name: Pollution Control Services		Address: P.O. Box 117, Gorham, ME 04038		Phone: 892-0884		Permit Issued: JUL 10 1997	
Past Use: Comm		Proposed Use: Same		COST OF WORK: \$		PERMIT FEE: \$ 40.00	
				FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type:	
Proposed Project Description: Remove Four Underground Tanks				Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>	
Permit Taken By: Mary Grevik		Date Applied For: 08 July 1997		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied: <input type="checkbox"/>		Zoning Approval: Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
				Signature: _____		Date: _____	



1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

- Zoning Appeal**
- Variance
 - Miscellaneous
 - Conditional Use
 - Interpretation
 - Approved
 - Denied

- Historic Preservation**
- Not in District or Landmark
 - Does Not Require Review
 - Requires Review

- Action:**
- Approved
 - Approved with Conditions
 - Denied

Date: 7/10/97

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT **Dina Patton** ADDRESS: _____ DATE: **08 July 1997** PHONE: _____

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE _____ PHONE: _____

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector



City of Portland, Maine - Building or Use Permit Application

634-C-009

389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 185 Kennebec St		Owner: Aronson, Dick		Phone:		Permit No: 970729 PERMIT ISSUED Permit Issued: JUL 10 1997 CITY OF PORTLAND		
Owner Address:		Lessee/Buyer's Name: Century Tire		Phone:			Business Name:	
Contractor Name: Pollution Control Services		Address: P.O. Box 117 Gorham, ME 04038		Phone: 892-0884			Zone: B-5 CBL: 034 C 009	
Past Use: Comm		Proposed Use: Same		COST OF WORK: \$			PERMIT FEE: \$ 40.00	
Proposed Project Description: Remove Four Underground Tanks				FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type:		
				Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>		
				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied		
Permit Taken By: Mary Gresik		Date Applied For: 08 July 1997						

Zoning Approval:
[Signature] 7/9/97
Special Zone or Reviews:
 Shoreland
 Wetland
 Flood Zone
 Subdivision
 Site Plan maj minor mm

Zoning Appeal
 Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation
 Not in District or Landmark
 Does Not Require Review
 Requires Review

Action:
 Approved
 Approved with Conditions
 Denied
 Date: 7/9/97
[Signature]

PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT: *[Signature]* Dina Patton ADDRESS: DATE: 08 July 1997 PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT 2
A. Rowe

Aronson, Adele

~~08-28-97~~

**NOTICE OF INTENT
TO ABANDON (REMOVE) AN
UNDERGROUND OIL STORAGE FACILITY**

THIS FORM MUST BE FILED WITH THE D.E.P. AND YOUR LOCAL FIRE DEPARTMENT AT LEAST 30 DAYS PRIOR TO THE SCHEDULED REMOVAL

PLEASE TYPE OR PRINT IN INK:

Name of Facility Owner: Century Tire Co.
Mailing Address: 185 Kennebec St. Telephone #: 207-775-3777
City: Portland State: ME Zip Code: 04101
Contact Person (name, address & telephone #): Dick Aronson - 185 Kennebec St.
Portland ME, 04101
Name of Facility: Century Tire Co. Registration #: 316
Facility Location (town & street): 185 Kennebec St. 52 St. John St. Portland

1. Identify the tanks at this location which are going to be removed:

Tank #	Tank Age	Tank Size (gallons)	Type of Product Stored
1	17	3000	gas
2	17	4000	gas
3	17	2000	#2 F.O.
4	17	500	Waste Oil
5	30	3000	#2 F.O.

2. Directions to this facility (be specific):
95 to Franklin St. at an marginal way - 185 Kennebec
95 to Commercial St. to St. John

3. Is or was the tank(s) used to store Class I liquids (e.g. gasoline, jet fuel)? Yes No
IF YES, REMOVAL OF THE TANK(S) MUST BE DONE UNDER THE DIRECTION OF A CERTIFIED TANK INSTALLER.

Tank Installer's Name: Jeff. Eaton Certification Number: 8363 Signature: Jeff. Eaton

4. Environmental site assessments are required for all tanks except those used for storing heating oil, not for resale, or for farm or residential motor fuel tanks under 1,100 gallons where the product is used on site. Site Assessor's Name and Address (if applicable):

Environmental Services Remediation 207-825-1272

5. Name and telephone number of contractor who will do the tank removal:

Pollution Control Services 207-892-1514

6. Expected date of removal (month/day/year): 7/21/97

I hereby provide Notice that I intend to properly abandon the underground oil storage facility as described above.

Date: 6/2/97 Signature: Richard D. Aronson
Printed Name and Title: RICHARD D. ARONSON PRES.

Mail original and yellow copy to DEP; pink copy to fire department; retain gold copy.
RETURN POSTCARD AFTER TANK(S) HAS BEEN REMOVED


FIRE CODE PERMIT REPORT

DATE: 7/8/97 ADDRESS: 185 Kennebunk ST
 PERMIT TO: Pollution Control Services
 OWNER/CONTRACTOR: Aronson
 APPROVED ✓ DENIED _____

CONDITIONS OF APPROVAL/DENIAL

1. The boiler or furnace shall be protected by enclosing with one hour fire rated construction including fire doors and ceiling or by providing automatic extinguishment and smoke protected enclosure. Sprinkler piping serving not more than six sprinklers may be connected to a domestic water supply system having a capacity sufficient to provide a 0.15 gpm, per square foot of floor throughout the entire area. An indicating shut-off valve shall be installed in an accessible location between the sprinkler and the connection to the domestic water supply. Minimum pipe size shall be 3/4 inch copper or 1 inch steel. Maximum coverage area of a residential sprinkler is 144 square feet per sprinkler.
2. All required Fire Alarm Systems shall have the capability of "Zone Disconnect" via switches or key pad program provided the method is approved by the Fire Prevention Bureau.
3. All remote annunciators shall have a visible "trouble" indicator along with the Fire Alarm "Zone" indicators.
4. Any Master Box connected to the Municipal Fire Alarm System shall have a supervised Municipal Disconnect Switch.
5. All Master Box locations shall be approved by the Fire Department Director of Communications. A Master Box shall be located so that the center of the box is five feet above finished floor.
6. All Master Box locations are required to have a locked box (knoxbox).
7. A fire alarm acceptance report shall be submitted to the Portland Fire Department.
8. All underground tank removal(s) and/or installation(s) shall be done in accordance with the Department of Environmental Regulations (Chapter 691).
9. No cutting of tanks on site. Cutting of tanks is to be done at an approved tank disposal site.
10. Fire Dispatcher must be at least 48 hours in advance of removal and/or transportation of tanks.
11. All above ground L/P storage tanks shall be located in accordance with NFPA 58 Standards.
12. Any tank located near the path of vehicle movement shall be protected with appropriate permanent barricades.

13. All piping shall be protected from possible mechanical damage and vandalism.
14. A 4" Storz fire department connection is required.
15. Any new sprinkler construction over six sprinkler heads needs to have State Fire Marshal approval.
16. Any renovations of sprinkler systems over 20 sprinkler heads needs to have State Fire Marshal approval.
17. A sprinkler performance test shall be submitted to the Portland Fire Department after completion of sprinkler work.
18. State Fire Marshal approval is required for this project.



Lt. G. McDougall
Fire Prevention Officer
City of Portland