PORTLAND PUMP COMPANY
Fuel System Specialists

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/13/14

To: Ann Machado
Zoning Specialist
City of Portland

From: Rik Jordan
Portland Pump Co.

Re: Century Tire
185Kennebec Street
Portland Maine

Portland Pump was contracted to excavate an area at the Century Tire location to determine if there was an. underground tank in the parking lot on the Kennebec St. side. MAI Environmental and Portland pump did find a 3,000 gallon tank on site we contact the DEP they gave us permission to remove the tank and showed up on site shortly after to observe and ask a few questions. The tank was had water in it was pumped out by Enpro and tank was removed.

I have been in touch with DEP and in the process of filling out the necessary paper work for them. I will forward copies to you when I have them all signed.

Please let me know if you have any questions.

If you have any questions please feel free to contact me

Sincerely,

Rik Jordan