DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

VANDELAY INDUSTRIES LLC

Located at

195 KENNEBEC ST (Building A)

PERMIT ID: 2016-01980

ISSUE DATE: 09/22/2016

CBL: 034 C009001

has permission to **Ch**

Change of Use and tenant fit up in existing building - fit-up for fitness studio, "Orange Theory Fitness Centre".

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Department

/s/ Michael White

/s/ Laurie Leader

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building A- Suite 3 - personal health and wellness facility

Building Inspections

Type: 5B

Fitness Studio Occupant load = 29 Building is sprinkled BLDG. A - SUITE 3

Use Group: B

MUBEC/IBC 2009

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases 6 months.
- If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop W Order" and subsequent release to continue.

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping
Above Ceiling Inspection
Electrical Close-in w/Fire & Draftstopping
Final - Electric
Final - Fire
Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

PERMIT ID: 2016-01980 Located at: 195 KENNEBEC ST (Building A) CBL: 034 C009001

City of Portland, Maine - Building or Use Permit Permit No: Date Applied For: CBL: 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 2016-01980 07/27/2016 034 C009001

Proposed Use:

personal health and wellness facility

Proposed Project Description:

Change of Use and tenant fit up in existing building - fit-up for fitness studio, "Orange Theory Fitness Centre".

Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 09/22/2016

Note: B-7 Ok to Issue: ✓

section 14-295(a)(21) Health clubs, martial arts, personal health and wellness facilities

parking requirement reviewed as part of Level II site plan

Conditions:

1) Separate permits shall be required for any new signage.

2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.

Dept: Building Inspecti **Status:** Approved w/Conditions **Reviewer:** Laurie Leader **Approval Date:** 09/22/2016 **Note:** Ok to Issue: ✓

Conditions:

- 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

Dept: Engineering DPS **Status:** Not Applicable **Reviewer:** Rachel Smith **Approval Date:** 07/29/2016 **Note:** Ok to Issue: ✓

Conditions:

1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact 207-874-8801

Dept: Fire **Status:** Approved w/Conditions **Reviewer:** Michael White **Approval Date:** 09/06/2016 **Note:** Ok to Issue: ✓

Conditions:

- 1) A separate Fire Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.
- 2) A Knox Box is required.
- 3) A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.
- 4) Fire extinguishers are required per NFPA 1 (2009 Edition) Table 13.6.2. Placement and Size of extinguishers shall follow NFPA 1 table 13.6.8.2.1.1.
- 5) Means of egress shall be illuminated in accordance with 2009 NPFA 101, Chapter 7.8.
- 6) New construction projects (regardless if cost) involving: Educational, Health Care, Places of Assembly, Mercantile A & B, Hotel/Motel/Dormitory, Lodging and Rooming, Business.
- 7) All means of egress to remain accessible at all times.
- 8) All construction shall comply with 2009 NFPA 101, Chapter 36 New Mercantiule Occupancies.

- 9) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).
- 10 All construction shall comply with City Code, Chapter 10.

PERMIT ID: 2016-01980 Located at: 195 KENNEBEC ST (Building A) CBL: 034 C009001