

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

VANDELAY INDUSTRIES LLC

**Located at**

195 KENNEBEC ST (Building A)

**PERMIT ID:** 2016-02665

**ISSUE DATE:** 10/25/2016

**CBL:** 034 C009001

has permission to **For the installation of additional fire alarm devices and to tie into the existing fire alarm system.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

|   |  |
|---|--|
| Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED. | A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy. |
|---|--|

*/s/ Michael White*

*/s/ Michael Russell, MS, Director*

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*  
Fitness Center

*Building Inspections*

*Fire Department*

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

## **REQUIRED INSPECTIONS:**

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

|  |                                      |   |  |   |
|--|--------------------------------------|---|--|---|
| <b>City of Portland, Maine - Building or Use Permit</b>  |                                      | <b>Permit No:</b><br>2016-02665   | <b>Date Applied For:</b><br>10/12/2016 | <b>CBL:</b><br>034 C009001                              |
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716  |                                      |   |  |   |
| <b>Proposed Use:</b><br>Same: Building A - ("Orange Theory Fitness Center")  |                                      | <b>Proposed Project Description:</b><br>For the installation of additional fire alarm devices and to tie into the existing fire alarm system. |  |   |
| <b>Dept:</b> Zoning  | <b>Status:</b> Approved              | <b>Reviewer:</b> Christina Stacey   | <b>Approval Date:</b> 10/24/2016       |   |
| <b>Note:</b>   |                                      |   |  | <b>Ok to Issue:</b> <input checked="" type="checkbox"/> |
| <b>Conditions:</b>   |                                      |   |  |   |
| <b>Dept:</b> Fire  | <b>Status:</b> Approved w/Conditions | <b>Reviewer:</b> Michael White  | <b>Approval Date:</b> 10/13/2016       |   |
| <b>Note:</b>   |                                      |   |  | <b>Ok to Issue:</b> <input checked="" type="checkbox"/> |
| <b>Conditions:</b>   |                                      |   |  |   |
| <ol style="list-style-type: none"> <li>1) The fire alarm system shall have a new fire alarm inspection sticker.</li> <li>2) The fire alarm technician shall be present for the fire inspection. System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8400 to schedule.</li> <li>3) All smoke alarms shall be photoelectric.</li> <li>4) The Fire Alarm installation shall comply with the following: City of Portland Chapter 10, Fire Prevention and Protection; NFPA 1, Fire Code (2009 edition), as amended by City Code; NFPA 101, Life Safety Code (2009 edition), as amended by City Code; City of Portland Fire Department Rules and Regulations; NFPA 72, National Fire Alarm and Signaling Code (2010 edition), as amended by Fire Department Rules and Regulations; and NFPA 70, National Electrical Code (2011 edition) as amended by the State of Maine.</li> <li>5) A Knox Box is required.</li> </ol> |                                      |   |  |   |