NFPA 101 TABLE 7.3.1.2
OCCUPANT LOAD:

1,367 SF OF MERCANTILE USE =	46 PEOPLE
159 SF OF STORAGE USE=	.5 PEOPLE
11,334 SF OF BUSINESS USE=	13 PEOPLE
TOTAL	**(59.5) 60 PEOPLE**

NFPA 101 -2015
CHAPTER 35 - NEW MERCANTILE OCCUPANCIES

LONGEST COMMON PATH OF TRAVEL SHALL NOT EXCEED 100 FEET IN MERCANTILE OCCUPANCIES WITH LOW TO ORDINARY HAZARD AND PROTECTED BY AN APPROVED, SUPERVISED AUTOMATIC SPRINKLER SYSTEM

LONGEST TRAVEL DISTANCE TO EXITS SHALL NOT EXCEED 250 FEET IN A MERCANTILE OCCUPANCIES CLASSIFIED AS ORDIANRY HAZARD IN BUILDINGS PROTECTED BY AN APPROVED, SUPERVISED AUTOMATIC SPRINKLER SYSTEM,

LONGEST DEAD-END CORRIDORS SHALL NOT EXCEED 50 FEET IN A SPRINKLERED BUILDING

8' 4' 2' 0

N

ELECTRICAL & LIFE SAFETY KEY:

NOTE:
NEW DEVICES AND WORK ARE SHOWN IN BOLD.
EXISTING DEVICES ARE INDICATED IN GRAY.
EXISTING VOICE / DATA LINES ARE TO REMAIN AND BE RE-USED.

- EXIT LIGHT FIXTURE
- EMERGENCY LIGHTING
- COMBO EXIT SIGN / EMERGENCY LIGHTING
- H — FIRE ALARM SYSTEM - HORN/ STROBE
- S — FIRE ALARM SYSTEM - STROBE
- P — FIRE ALARM SYSTEM - PULL STATION

1 FLOOR PLAN- LIFE SAFETY

SCALE: 1/4" = 1'-0"

CITY PERMIT SET
7-25-2017

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND SHALL REMAIN THE PROPERTY OF WHIPPLE CALLENDER ARCHITECTS. IT SHALL NOT BE USED FOR ANY OTHER PURPOSE THAT FOR WHICH IT IS SPECIFICALLY FURNISHED

Reviewed for Code Compliance
Inspections Division
Portland, Maine
Date: 09/11/17

COASTAL PHARMACY & WELLNESS
195 KENNEBEC STREET
PORTLAND, ME 04101

LICENSED ARCHITECT
ANNE E. CALLENDER
No. 1861
STATE OF MAINE

WHIPPLE CALLENDER ARCHITECTS
PO BOX 1276
PORTLAND, ME 04101
P 207.775.2696
F 207.775.3631
www.whipplecallender.com

MARK	DATE	DESCRIPTION

DATE: 7/25/17
CHECKED BY: #Contact Full Name
DRAWN BY: GLL
JOB: #Pln
SHEET TITLE: FLOOR PLAN LIFE SAFETY

A1.2